

Water Services Planning Report

Register Reference No.: SD21A/0179

Development: Removal of selected hedging, the removal of the existing 52 car parking spaces and the construction of a 4-storey apartment building with setbacks at third floor level, total 14 apartments comprising of 1 one-bedroom, 11 two bedroom; 2 three bedroom apartments, all with associated private open spaces areas in the form of balconies; access to the development from existing vehicular and pedestrian entrance from Leixlip Road (R835) and from proposed new vehicular and pedestrian access from Ardeevin Drive; all with associated landscaped courtyard at ground floor level, sedum roof (main roof), bicycle storage, bin storage, signage, associated drainage and site development works (Protected Structure RPS No. 094).

Location: Ball Alley House, Leixlip Road, Lucan, Co. Dublin

Report Date : 30th July 2021

Surface Water Report:

No objection subject to:

1.1 Submit a drawing showing cross sectional details of all proposed SuDS (Sustainable Drainage Systems) features ie. Green roofs and Permeable Paving

Flood Risk

No Objection:

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
 - All new precast surface water manholes shall have a minimum thickness surround of 150mm Concrete Class B.
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
-

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Ronan Toft AE

Date: _____

Endorsed: _____
Chris Galvin SE.

Date: _____