

Water Services Planning Report

Register Reference No.: SD21A/0201
Development: Retention of original garage converted into a hair dressing salon; internal alterations and part front elevation.
Location: 17, Killakee Court, Dublin 24
Report Date : 16/08/2021

Surface Water Report:

No objection subject to:

Flood Risk

No Objection Subject To:

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
-

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Brian Harkin SEE.

Date: _____

Endorsed: _____
Chris Galvin SE.

Date: _____