

Water Services Planning Report

Register Reference No.: SD21B/0392

Development: Single storey flat roof porch extension of 4.5sq.m to the front; single storey flat roof extension of 7sq.m and renovation to the rear with 3 rooflights; conversion of existing hip roof to a dutch gable roof; conversion of attic space to storage space with 1 rooflight to the front and dormer window to the rear and all associated site works.

Location: 179, Templeville Road, Dublin 6w

Application Type: Permission

Report Date: 17th August 2021

Surface Water Report:

Further Information Required:

1.1 There are no soil percolation test results, design calculations or dimensions submitted for the proposed soakaway. The applicant is required to submit a report showing site specific soil percolation test results and design calculations for the proposed soakaway in accordance with BRE Digest 365 – Soakaway Design.

1.2 The applicant is required to submit a revised drawing showing plan & cross-sectional views, dimensions, and location of proposed soakaway. Any proposed soakaway shall be located fully within the curtilage of the property and shall be:

- i) At least 5m from any building, public sewer, road boundary or structure.
- ii) Generally, not within 3m of the boundary of the adjoining property.
- iii) Not in such a position that the ground below foundations is likely to be adversely affected.
- iv) 10m from any sewage treatment percolation area and from any watercourse / floodplain.
- v) Soakaways must include an overflow connection to the surface water drainage network.

1.3 The applicant shall include Water Butts as part of Sustainable Drainage Systems (SuDS) measures for the proposed development.

- All works shall comply with the Building Regulations -Technical guidance document- Part H Drainage and Wastewater disposal
 - The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
-

Water Services Planning Report

Flood Risk Report:

No objection:

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Ronan Toft AE

Date: _____

Endorsed: _____
Brian Harkin SEE

Date: _____