

## 11.0 NOISE AND VIBRATION

### 11.1 INTRODUCTION

This chapter of the Environmental Impact Assessment Report (EIAR) describes the assessment undertaken of the potential noise and vibration impact from the proposed power plant on local residential amenity and commercial properties.

Some 16 no. noise assessment locations have been identified that are representative of the nearest residential, commercial and amenity locations. The nearest occupied noise sensitive locations (NSL) are located some 400 m to the south of the site (i.e. R001) and some 450 m to the north east (i.e. R014). The closest amenity to the development is Grangecastle Golf Course (i.e. R015) which is located to the east of the development lands.

Noise and vibration impact assessments for the nearest NSLs have been prepared for the construction and operational phase of the proposed power plant. To inform this assessment baseline noise levels have been measured in the vicinity of a number of NSLs surrounding the proposed power plant. Noise predictions to the nearest NSLs have been prepared for both the construction and operational phases.

Other developments in the area (operational or permitted) with the potential for cumulative effects were identified and assessed as part of this assessment.

For a glossary of terms used in this chapter please refer to Appendix 11-1.

#### *11.1.1 STATEMENT OF AUTHORITY*

This chapter of the EIAR has been prepared by the following staff of AWN Consulting Ltd:

Damian Kelly (Director) holds a B.Sc. from DCU and a M.Sc. from QUB. He has over 20 years' experience as an acoustic consultant and is a Member of the Institute of Acoustics. He has extensive knowledge in the field of noise modelling and prediction, having developed many of the largest and most complex examples of proprietary noise models prepared in Ireland to date. He has extensive modelling experience in relation to wind farm, industrial and road infrastructure projects. He is a sitting member of the committee of the Irish Branch of the Institute of Acoustics.

#### *11.1.2 FUNDAMENTALS OF ACOUSTICS*

A sound wave travelling through the air is a regular disturbance of the atmospheric pressure. These pressure fluctuations are detected by the human ear, producing the sensation of hearing. To take account of the enormous range of pressure levels that can be detected by the ear, it is widely accepted that sound levels are measured and expressed using a decibel scale i.e. a logarithmic ratio of sound pressures. These values are expressed as Sound Pressure Levels (SPL) in decibels (dB).

The audible range of sounds expressed in terms of Sound Pressure Levels (SPL) is from 0 dB (for the threshold of hearing) to 120 dB (for the threshold of pain). In general, a subjective impression of doubling of loudness corresponds to a tenfold increase in sound energy which conveniently



**Profile Park Power Plant – Environmental Impact Assessment Report**

equates to a 10 dB increase in SPL. It should be noted that a doubling in sound energy (such as may be caused by a doubling of traffic flows) increases the SPL by 3 dB.

The frequency of sound is the rate at which a sound wave oscillates and is expressed in Hertz (Hz). The sensitivity of the human ear to different frequencies in the audible range is not uniform. For example, hearing sensitivity decreases markedly as frequency falls below 250Hz. In order to rank the SPL of various noise sources, the measured level has to be adjusted to give comparatively more weight to the frequencies that are readily detected by the human ear. The 'A-weighting' system defined in the international standard, BS ISO 226:2003 *Acoustics. Normal Equal-loudness Level Contours* has been found to provide the best correlations with human response to perceived loudness. SPLs measured using 'A-weighting' are expressed in terms of dB(A).

An indication of the level of some common sounds on the dB(A) scale is presented in Figure 11-1.




Figure 11-1: dB(A) Scale & Indicative Noise Levels – (EPA: Guidance Note for Noise: Licence Applications, Surveys and Assessments in Relation to Scheduled Activities (NG4 – 2016))

## 11.2 METHODOLOGY

The assessment of impacts for the proposed power plant have been undertaken with reference to the most appropriate guidance documents relating to environmental noise and vibration which are set out in Section 11.2.3. In addition to these specific guidance documents, the following guidelines were considered and consulted for the purposes of this chapter:

- EPA Guidelines on the Information to be contained in Environmental Impact Statements, (EPA, 2002);
- EPA Advice Notes on Current Practice (in the preparation of Environmental Impact Statements), (EPA, 2003);
- EPA Guidelines on the Information to be contained in Environmental Impact Assessment Reports Draft August 2017 (EPA, 2017); and
- EPA Advice Notes for Preparing Environmental Impact Statements, (Draft, September 2015).

The assessment methodology undertaken for this assessment is summarised as follows:

- Review of the most applicable standards and guidelines to set acceptable noise and vibration criteria for the construction and operational phases of the proposed power plant;
- Characterise the receiving environment through baseline noise surveys at various NSLs surrounding the proposed power plant;
- Undertake predictive calculations to assess the potential impacts associated with the construction phase of the proposed power plant at NSLs;
- Undertake predictive calculations to assess the potential impacts associated with the operational phase of the proposed power plant at NSLs;
- Specify mitigation measures to reduce, where necessary, the identified potential outward impacts relating to noise and vibration from the proposed power plant;
- Describe decommissioning phase effects; and
- Describe the significance of the residual noise and vibration effects associated with the proposed power plant.

### 11.2.1 GUIDANCE DOCUMENTS AND ASSESSMENT CRITERIA

The following sections review best practice guidance that is commonly adopted in relation to developments such as the one under consideration here.

#### 11.2.1.1 Construction Phase Noise

There is no published statutory Irish guidance relating to the maximum permissible noise level that may be generated during the construction phase of a project. Local authorities normally control construction activities by imposing limits on the hours of operation and may consider noise limits at their discretion.

In the absence of specific noise limits, appropriate criteria relating to permissible construction noise levels for a development of this scale may be found in the British Standard BS 5228-1:2009+A1:2014 *Code of practice for noise and vibration control on construction and open sites – Noise*.



**Profile Park Power Plant – Environmental Impact Assessment Report**

The approach adopted here calls for the designation of an NSL into a specific category (A, B or C) based on existing ambient noise levels in the absence of construction noise. A threshold noise value is applied to each category. Exceedances (construction noise only) of the threshold value, at the facade of a sensitive receptor during construction, indicates a potential significant noise impact associated with the construction activities. The threshold values recommended by BS5228-1 are depicted in Table 11-1.

*Table 11-1: Example Threshold Potential Significant Effect at Dwellings*

Assessment category and threshold value period (τ)	Threshold value, in L <sub>Aeq,T</sub> dB		
	Category A <small>Note A</small>	Category B <small>Note B</small>	Category C <small>Note C</small>
Night-time (23:00 to 07:00hrs)	45	50	55
Evenings and weekends <small>Note D</small>	55	60	65
Daytime (07:00 – 19:00hrs) and Saturdays (07:00 – 13:00hrs)	65	70	75

- Note A            Category A: threshold values to use when ambient noise levels (when rounded to the nearest 5dB) are less than these values.
- Note B            Category B: threshold values to use when ambient noise levels (when rounded to the nearest 5dB) are the same as category A values.
- Note C            Category C: threshold values to use when ambient noise levels (when rounded to the nearest 5dB) are higher than category A values.
- Note D            19:00 – 23:00 weekdays, 13:00 – 23:00 Saturdays and 07:00 – 23:00 Sundays.

It should be noted that this assessment method is only valid for residential properties.

For the appropriate period (e.g. daytime) the ambient noise level is determined and rounded to the nearest 5 dB. Based on review of baseline noise monitoring to hand the relevant BS5228-1 threshold values at the various assessment locations are discussed in the relevant section of this report.

Guidance on the degree of significance is presented the UK document Design Manual for Roads and Bridges (2020) *LA 111 Sustainability & Environmental Appraisal. Noise and Vibration Rev 2*. The approach is as follows:

- to determine the threshold value for construction noise according to the method from BS5228 described above and
- to compare the predicted construction noise level with the existing noise levels and the threshold value according to the criteria in Table 11-2 below.

Potentially this procedure is to be followed separately for each noise-sensitive location, however in this instance as the existing noise levels at all survey locations correspond in Category A according to table above, all noise-sensitive locations are considered together.

Similarly, for this proposed power plant the vast majority of construction works will take place within the ‘Daytime’ period, i.e. 07:00 – 19:00 on Mondays to Fridays and 07:00 – 13:00 on Saturdays.

The magnitude of the construction noise impact according the DMRB is mapped to the EPA significance terms as detailed in Table 11-2.



**Profile Park Power Plant – Environmental Impact Assessment Report**

*Table 11-2: Description of the magnitude of impacts. Adapted from DMRB Table 3.16*

Predicted Construction Noise Level is	Magnitude of Impact (DMRB)	EPA Significance of Effect
Below or equal Baseline Noise Level	Negligible	Not Significant
Above Baseline and below or equal to threshold	Minor	Slight – Moderate
Above threshold and below or equal to threshold + 5dB	Moderate	Moderate – Significant
Above threshold + 5dB	Major	Significant – Very Significant

Taking the above into account, it is considered that the 65dB  $L_{Aeq,1hr}$  is a suitable criterion for daytime construction noise at residential and amenity noise-sensitive locations and 70 dB  $L_{Aeq,1hr}$  at commercial locations.

**11.2.1.2 Construction Phase Vibration**

Vibration standards come in two varieties: those dealing with human comfort and those dealing with cosmetic or structural damage to buildings. With respect to this development, the range of relevant criteria used for building protection is expressed in terms of Peak Particle Velocity (PPV) in mm/s.

Guidance relevant to acceptable vibration within buildings is contained in the following documents:

- British Standard BS 7385 – Evaluation and measurement for vibration in buildings – Part 2: Guide to damage levels from ground borne vibration (BSI, 1993); and
- British Standard BS 5228-2:2009+A1:2014 – Code of practice for noise and vibration control on construction and open sites – Part 2: Vibration (BSI, 2014).

BS 7385 states that there should typically be no cosmetic damage if transient vibration does not exceed 15 mm/s at low frequencies rising to 20 mm/s at 15 Hz and 50 mm/s at 40 Hz and above. These guidelines relate to relatively modern buildings and should be reduced to 50% or less for more critical buildings.

BS 5228 recommends that, for a soundly constructed residential property and similar structures that are generally in good repair, a threshold for minor or cosmetic (i.e. non-structural) damage should be taken as a peak particle velocity of 15 mm/s for transient vibration at frequencies below 15 Hz and 20 mm/s at frequencies above than 15 Hz. Below these vibration magnitudes minor damage is unlikely, although where there is existing damage these limits may be reduced by up to 50%. In addition, where continuous vibration is such that resonances are excited within structures the limits discussed above may need to be reduced by 50%.

The Transport Infrastructure Ireland (TII) (formerly National Roads Authority (NRA)) publication *Guidelines for the Treatment of Noise and Vibration in National Road Schemes (NRA, 2004)* also contains information on the permissible construction vibration levels during the construction phase as shown in Table 11-3.



**Profile Park Power Plant – Environmental Impact Assessment Report**

*Table 11-3: Allowable Vibration at Sensitive Properties (NRA, 2004)*

Allowable vibration (in terms of peak particle velocity) at the closest part of sensitive property to the source of vibration, at a frequency of		
Less than 10 Hz	10 to 50 Hz	50 to 100 Hz (and above)
8 mm/s	12.5 mm/s	20 mm/s

Following review of the guidance documents set out above, the values are considered appropriate for this assessment as they provide more stringent vibration criteria.

**11.2.1.3 Additional Vehicular Activity on Public Roads**

There are no specific guidelines or limits relating to traffic related sources along the local or surrounding roads. Given that traffic from the development will make use of existing roads already carrying traffic volumes, it is appropriate to assess the calculated increase in traffic noise levels that will arise because of vehicular movements associated with the development.

For the assessment of potential noise impacts from construction related traffic along public roads and haul routes it is proposed to adopt guidance from *Design Manual for Roads and Bridges* (DMRB), Highways England, Transport Scotland, The Welsh Government and The Department of Infrastructure 2019.

Table 11-4, taken from Section 13.17 of DMRB presents guidance as to the likely impact associated with any change in the background noise level ( $L_{Aeq,T}$ ) at a noise sensitive receiver as a result of construction traffic.

Section 3.19 of DMRB states that construction noise and construction traffic noise shall constitute a significant effect where it is determined that a major or moderate magnitude of impact will occur for a duration exceeding:

- 10 or more days or nights in any 15 consecutive days or nights;
- A total number of days exceeding 40 in any 6 consecutive months.

*Table 11-4: Likely Impacts Associated with Change in Traffic Noise Level (Source: Table 3.17, DMRB, 2020).*

Change in Sound Level (dB $L_{A10}$ )	Magnitude of Impact
<1.0	Negligible
1.0 – 2.9	Minor
3.0 – 4.9	Moderate
5+	Major

The guidance outlined in Table 11-4 will be used to assess the predicted increases in traffic levels on public roads associated with the proposed power plant and comment on the likely short-term impacts during the construction phase.

**11.2.2 OPERATIONAL PHASE NOISE**

The relevant local authority, South Dublin County Council (SDCC), does not have any standard noise conditions listed in the *Dublin Agglomeration Environmental Noise Action Plan December 2018 – November 2023 – Volume 4: South Dublin County Council*. Therefore, consideration has



**Profile Park Power Plant – Environmental Impact Assessment Report**

been given to the following best practice and national guidance and a review of planning conditions recently applied to similar developments in the area.

**11.2.2.1 EPA – NG4**

In order to establish whether the noise sensitive locations in the vicinity of the site would be considered ‘low background noise’ areas as defined in the Environmental Protection Agency (EPA) publication Guidance Note for Noise: Licence Applications, Surveys and Assessments in Relation to Scheduled Activities (NG4 2016) guidance, the noise levels measured during the environmental noise survey need to satisfy the following criteria:

- Arithmetic Average of  $L_{A90}$  During Daytime Period  $\leq 40$  dB  $L_{A90}$ , and;
- Arithmetic Average of  $L_{A90}$  During Evening Period  $\leq 35$  dB  $L_{A90}$ , and;
- Arithmetic Average of  $L_{A90}$  During Night-time Period  $\leq 30$  dB  $L_{A90}$ .

*Determining Appropriate Noise Criteria*

Table 11-5 outlines the noise emission limit criteria detailed in the NG4 document.

*Table 11-5: NG4 Approach for Determining Appropriate Noise Criteria*

Scenario	Daytime Noise Criterion, dB $L_{Ar,T}$ (07:00 to 19:00hrs)	Evening Noise Criterion, dB $L_{Ar,T}$ (19:00 to 23:00hrs)	Night Noise Criterion, dB $L_{Aeq,T}$ (23:00 to 07:00hrs)
Areas of Low Background Noise	45dB	40dB	35dB
All Other Areas	55dB	50dB	45dB

Based on a review of the noise data to hand in the vicinity of the development site, the noise sensitive locations in the vicinity of the site are not defined as areas of low background noise as per the NG4 guidance, As the proposed power plant will operate on a 24-hour basis, the potential impact during night-time periods governs this assessment. Therefore, a night-time criterion 45dB  $L_{Aeq,T}$  would be applied to normal operations of the site.

Note that if the proposed power plant were designed to this level, plant noise would be a clearly audible source of noise at number of noise sensitive locations in close proximity of the development. It would be expected that such levels would give rise to complaints at nearby noise sensitive locations. It should be noted that the design has been mitigated to offset this occurring.

Note the following statements from NG4:

*“Where there may be a question as to the bona fides of the complaint or any residual dispute following an initial investigation, an objective assessment should be undertaken in accordance with the guidance set out in BS 4142: 2014: Methods for rating and assessing industrial and commercial sound.*

*In situations where there are reasonable grounds for annoyance and/or licence limits are exceeded, prompt remedial action should be taken by the licensee and BAT should be used to resolve the problem and to minimise the noise impact.”*



## Profile Park Power Plant – Environmental Impact Assessment Report

Therefore, while a site may be compliant with the EPA limits the above would infer that a BS 4142 assessment may still confirm the validity of a complaint. Therefore consideration should also be given to this guidance.

### 11.2.2.2 BS 4142:2014

BS 4142:2014+A1:2019: *Methods for rating and assessing industrial and commercial sound* is the industry standard method for analysing building services plant sound emissions to residential receptors. BS 4142 describes methods for rating and assessing sound of an industrial and/or commercial nature. The methods described in this British Standard use outdoor sound levels to assess the likely effects of sound on people who might be inside or outside a dwelling or premises used for residential purposes upon which sound is incident. It should also be noted that the EPA NG4 document indicates that this assessment methodology should be used in the assessment of complaints associated with a site’s operations. Whilst the current site will be licenced, based on the NG4 extracts referenced above in relation to complaints, the guidance contained in BS 4142 needs to be given due regard.

For an appropriate BS 4142 assessment it is necessary to compare the measured external background sound level (i.e. the  $L_{A90,T}$  level measured in the absence of plant items) to the rating level ( $L_{Ar,T}$ ) of the various plant items, when operational. Where sound emissions are found to be tonal, impulsive, intermittent or to have other sound characteristics that are readily distinctive against the residual acoustic environment, BS 4142 advises that penalties be applied to the specific level to arrive at the rating level.

The subjective method for applying a penalty for tonal sound characteristics outlined in BS 4142 recommends the application of a 2dB penalty for a tone which is just perceptible at the receptor, 4dB where it is clearly perceptible, and 6dB where it is highly perceptible. In relation to intermittency, BS 4142 recommends that if the intermittency is readily distinguishable against the residual acoustic environment, a penalty of 3 dB can be applied. The following definitions as discussed in BS 4142 as summarised below:

<i>“ambient sound level, <math>L_{Aeq,T}</math>”</i>	equivalent continuous A-weighted sound pressure level of the totally encompassing sound in a given situation at any given time, usually from many sources near and far, at the assessment location over a given time interval, T.
<i>“residual sound level, <math>L_{Aeq,T}</math>”</i>	equivalent continuous A-weighted sound pressure level of the residual sound (i.e. ambient sound remaining at the assessment location when the specific sound source is suppressed to such a degree that it does not contribute to the ambient sound) at the assessment location over a given time interval, T.
<i>“specific sound level, <math>L_{Aeq,T}</math>”</i>	equivalent continuous A-weighted sound pressure level produced by the specific sound source at the assessment location over a given reference time interval, Tr.
<i>“rating level, <math>L_{Ar,T}</math>”</i>	specific sound level plus any adjustment for the characteristic features of the sound.





## Profile Park Power Plant – Environmental Impact Assessment Report

“background sound level,  $L_{A90,T}$ ” A-weighted sound pressure level that is exceeded by the residual sound at the assessment location for 90% of a given time interval, T, measured using time weighting F and quoted to the nearest whole number of decibels.

In order to establish an initial estimate of impact, BS 4142 states the following:

Obtain an initial estimate of the impact of the specific sound by subtracting the measured background sound level from the rating level, and consider the following.

- a. Typically, the greater this difference, the greater the magnitude of the impact.
- b. A difference of around +10 dB or more is likely to be an indication of a significant adverse impact, depending on the context.
- c. A difference of around +5 dB is likely to be an indication of an adverse impact, depending on the context.
- d. The lower the rating level is relative to the measured background sound level, the less likely it is that the specific sound source will have an adverse impact or a significant adverse impact. Where the rating level does not exceed the background sound level, this is an indication of the specific sound source having a low impact, depending on the context.

Adverse impacts include, but are not limited to, annoyance and sleep disturbance. Not all adverse impacts will lead to complaints and not every complaint is proof of an adverse impact.

The assessment methodology described above (i.e. comparison of rated sound level to background sound level) is quoted in BS 4142 as representing a methodology to ‘*obtain an initial estimate*’ of impact. It is important to note that BS 4142 also comments that ‘*Where the initial estimate of the impact needs to be modified due to the context, take all pertinent factors into consideration*’. BS 4142 provides a list of potential pertinent factors that can influence the ‘*initial estimate*’. The plant noise assessment conducted in the following sections has been carried out with consideration of the guidance contained in BS 4142 as summarised above.

Based on the noise monitoring summarised in Section 11.3, and considering the guidance contained in BS 4142 it would be considered that a suitable noise criterion for a development of this nature at residential locations would be the order of 37 to 39 dB(A). This would also need to consider any rating corrections that would be appropriate in relation to BS 4142.

### 11.2.2.3 Commercial Properties

A number of commercial / industrial properties are located in the vicinity of the site. In terms of noise missions from the site it is considered that an appropriate noise criterion at these locations is 55 dB  $L_{Aeq,15min}$ .

### 11.2.2.4 Golf Course Boundary

The adjacent golf course would be considered noise-sensitive and it is recommended that noise limits associated with the operations of the data centre would not exceed 55 dB  $L_{Aeq,15min}$  along



**Profile Park Power Plant – Environmental Impact Assessment Report**

the common boundary between the two sites in order to protect the recreational amenity of the facility.

**11.2.2.5 Comment on Low Frequency Noise**

Due to the nature of the development in question due consideration needs to be given to the issue of low frequency noise. A review of background noise levels and thresholds of hearing etc. has been considered and it is recommended that noise from the development does not exceed the following limits between 31.5Hz to 125Hz.

*Table 11-6: Suggested Low Frequency Noise Design Limit*

Item	Sound Pressure Level (dB) per Octave Band (Hz)		
	31.5	63	125
Limit	56	50	40

**11.2.2.6 Assessment of Significance**

The ‘*Guidelines for Environmental Noise Impact Assessment*’ produced by the Institute of Environmental Management and Assessment (IEMA) (2014) have been referenced in order to categorise the potential effect of changes in the ambient noise levels during the operational phases of the proposed power plant.

The guidelines state that for any assessment, the potential significance should be determined by the assessor, based upon the specific evidence and likely subjective response to noise. Due to varying factors which effect human response to environmental noise (prevailing environment, noise characteristics, time periods, duration and level etc.) assigning a subjective response must take account of these factors.

The scale adopted in this assessment is shown in Table 11-7 below and is based on an example scale within the IEMA guidelines. The corresponding significance of impact presented in the Draft ‘*Guidelines on the Information to be Contained in Environmental Impact Assessment Reports*’(EPA, 2017) is also presented.

The criteria above reflect the key benchmarks that relate to human perception of sound. A change of 3 dB(A) is generally considered to be the smallest change in environmental noise that is perceptible to the human ear. A 10 dB(A) change in noise represents a doubling or halving of the noise level. The difference between the minimum perceptible change and the doubling or halving of the noise level is split to provide greater definition to the assessment of changes in noise level.

It is considered that the criteria specified in the above table provide a good indication as to the likely significance of changes on noise levels in this case and have been used to assess the impact of operational noise.



Table 11-7: Operational Noise Impact Scale

Noise Level Change dB(A)	Subjective Response	Impact Guidelines for Noise Impact Assessment Significance (Institute of Acoustics)	Impact Guidelines on the Information to be contained in EIA Report's (EPA)
0	No change	None	Imperceptible
0.1 – 2.9	Barely perceptible	Minor	Not Significant
3.0 – 4.9	Noticeable	Moderate	Slight, Moderate
5.0 – 9.9	Up to a doubling or halving of loudness	Substantial	Significant
10.0 or more	More than a doubling or halving of loudness	Major	Very Significant, Profound

#### 11.2.2.7 Recommended Criteria

Following review of relevant guidance and examples of relevant planning permissions, the following noise criteria are proposed for the development:

**Day to Day Operation (Residential) – 37 to 39 dB  $L_{Aeq,15min}$**

**Day to Day Operation (Commercial) – 55 dB  $L_{Aeq,15min}$**

**Day to Day Operation (Grange castle Golf Course Boundary) – 55 dB  $L_{Aeq,15min}$**

Note plant noise emissions are to be designed such that they are not tonal and do not have impulsive characteristics at the nearest noise sensitive locations.

#### 11.2.2.8 Operational Phase Vibration

It should be noted that the day to day operation of the proposed power plant will not give rise to any significant levels of vibration off site and therefore the associated impact is not significant.

#### 11.2.2.9 Decommissioning Phase

In relation to the decommissioning phase, the criteria and limits outlined in the Construction Phase of the Proposed Project would be applicable as similar tools and equipment will be used.

### 11.2.3 EPA DESCRIPTION OF EFFECTS

The significance of effects of the proposed power plant shall be described in accordance with the EPA guidance document Draft Guidelines on the information to be contained in Environmental Impact Assessment Reports (EIAR), Draft, August 2017. Details of the methodology for describing the significance of the effects are provided in Chapter 1 (Introduction).



**Profile Park Power Plant – Environmental Impact Assessment Report**

The effects associated with the proposed power plant are described in the relevant sections of this chapter with respect to the EPA guidance and description of effects as set out in Chapter 1 (Introduction).

**11.2.3.1 Assessment Methodology**

The following guidance documents have been referenced to inform the assessment methodology; further details are presented where relevant in the various sections of this chapter.

**11.2.3.2 Background Noise Survey**

Baseline noise monitoring has been completed at a number of representative locations in the vicinity of the development and is reviewed here to inform a preliminary discussion of the existing noise environment.

**11.2.3.3 Choice of Measurement Locations**

Figure 11-2 illustrates the approximate location of the noise monitoring locations being considered here.



*Figure 11-2: Noise Monitoring Locations*

## Profile Park Power Plant – Environmental Impact Assessment Report

---

- Location A* Located to the north of the site in the vicinity of a number of dormer bungalows (R14) that are considered to be the closed noise sensitive residences to the north.
- Location B* Located to the north west of the site in the vicinity of R09.
- Location C* Located to the east of the site in the vicinity of the boundary with the Grangecastle golf course. This location would be considered to be representative of noise levels that would be experienced on the golf course itself.
- Location D* Located to the south of the site. The location would be considered to be representative of noise levels at Location R01 and background noise levels at properties along the Baldonnel Road (i.e. R02 to R05).

### 11.2.3.4 Measurement Periods

Noise measurements were conducted during typical day, evening and night-time periods. The night survey represents the time of night that provides a measure of existing background noise levels during a period where people are attempting to go to sleep or are sleeping. Due to the fact that the units in question here will operate on a 24-hour basis their potential impact during night-time periods is the critical issue. The survey was conducted during the following periods:

Surveys were completed during the following periods:

- Daytime 10:30 hrs to 14:25 hrs on 2 March 2021;
- Evening 21:34 hrs to 22:47 hrs on 2 March 2021, and;
- Night 22:53 hrs on 2 March 2021 to 01:21 hrs on 3 March 2021.

Weather conditions were dry and calm during all periods with temperatures of the order of 10°C during the daytime period, 5°C during the evening and 3°C during the night.

### 11.2.3.5 Instrumentation

A Brüel & Kjær Type 2250 Sound Level Meter (S/N 2818091) was used for all survey periods. Before, after and during each survey period, the measurement instrument was check calibrated using a Brüel & Kjær Type 4231 Sound Level Calibrator.

### 11.2.3.6 Measurement Procedure

Measurements were conducted at the locations noted above. Sample periods for the noise measurements were typically 15 minutes. The results were noted onto a Survey Record Sheet immediately following each sample and were also saved to the instrument memory for later analysis if required. Survey personnel noted the primary noise sources contributing to noise build-up.

### 11.2.3.7 Construction Noise Calculations

A variety of items of plant will be in use for the purposes of site preparation, construction and site works. There will be vehicular movements to and from the site that will make use of existing roads. There is the potential for generation of significant levels of noise from these activities.



## Profile Park Power Plant – Environmental Impact Assessment Report

---

Due to the nature of construction activities it is difficult to calculate the actual magnitude of emissions to the local environment in the absence of a detailed construction programme. The standard best practice approach is to predict typical noise levels at the nearest sensitive receptor using guidance set out in BS 5228-1:2009+A1:2014 *Code of practice for noise and vibration control on construction and open sites – Noise*. Construction noise predictions have been carried out using guidance set out in British Standard BS 5228-1:2009+A1:2014 *Code of practice for noise and vibration control on construction and open sites – Noise*.

The methodology adopted for the assessment of construction noise is to analyse the various elements of the construction phase in isolation. For each element, the typical construction noise sources are assessed along with typical sound pressure levels and spectra from BS 5228 at various distances from these works.

### 11.2.3.8 Operational Noise Calculations

A series of computer-based prediction models have been prepared to quantify the potential power plant noise level associated with the operational phase of the proposed power plant on the receiving environment. This section discusses the methodology behind the noise modelling process and presents the results of the modelling exercise.

### 11.2.3.9 DGMR iNoise V2020 Enterprise

The selected software, DGMR *iNoise Enterprise*, calculates noise levels in accordance with ISO 9613: *Acoustics – Attenuation of sound outdoors, Part 2: General method of calculation*, (ISO, 1996).

iNoise is a proprietary noise calculation package for computing noise levels and propagation of noise sources. iNoise calculates noise levels in different ways depending on the selected prediction standard. In general, however, the resultant noise level is calculated considering a range of factors affecting the propagation of sound, including:

- the magnitude of the noise source in terms of A weighted sound power levels (L<sub>WA</sub>);
- the distance between the source and receiver;
- the presence of obstacles such as screens or barriers in the propagation path;
- the presence of reflecting surfaces;
- the hardness of the ground between the source and receiver;
- Attenuation due to atmospheric absorption; and
- Meteorological effects such as wind gradient, temperature gradient and humidity (these have significant impact at distances greater than approximately 400 m).

### 11.2.3.10 Input Data and Assumptions

Buildings and information available for the site has been inputted into iNoise noise modelling software that implements *ISO 9613-2:1996 Acoustics – Attenuation of sound during propagation outdoors: General method of calculation*.

### 11.2.3.11 Noise Source Data

The noise modelling completed indicates the following limits in relation to various items of plant associated with the overall site development. Plant items will be selected in order to achieve the



**Profile Park Power Plant – Environmental Impact Assessment Report**

stated noise levels and or appropriate attenuation will be incorporated into the design of the plant/building in order that the plant noise emission levels are achieved on site (including any system regenerated noise).

Table 11-8 presents the noise data assumed for the various buildings. Data has been supplied by Greener Ideas Limited unless otherwise stated.

*Table 11-8: Summary of Noise Data for EIAR Noise Model*

Item	Octave Band Sound Power Level dB L <sub>w</sub>									dB	dB(A)
	31.5	63	125	250	500	1000	2000	4000	8000		
A – Intake Air (Opening) <sup>1</sup>	103	97	94	86	80	90	89	86	84	105	95
B – Exhaust Stack Outlet <sup>1</sup>	107	100	94	92	86	83	81	82	84	108	91
C – Radiator Coolers <sup>1</sup>	--	103	97	93	92	91	86	81	83	105	95
D – Air Exhaust Roof <sup>2</sup>	108	98	78	63	61	59	59	52	57	108	74
E – Roof <sup>3</sup>	79	72	70	66	59	51	46	34	31	80	61
F – Walls <sup>3</sup>	77	70	67	64	57	48	43	31	28	78	59
G – Ventilation Unit <sup>4</sup>	--	--	--	--	--	84	--	--	--	84	84
H – Gas AGI <sup>5</sup>	--	--	--	--	--	80	--	--	--	80	80
I – Gas PRS <sup>6</sup>	--	--	--	--	--	80	--	--	--	80	80
J – Transformer <sup>7</sup>	--	--	--	--	--	82	--	--	--	80	80

*Note 1* 6 in number. Data as supplied.

*Note 2* Based on assumption of a 25m<sup>2</sup> opening, 6 openings in the roof in total. Internal noise level within the building estimated as follows:

	L <sub>p</sub> - Octave Band Centre Frequency (Hz) - Linear									dB	dB(A)
	31.5	63	125	250	500	1000	2000	4000	8000		
Total L <sub>p</sub> Level in Hall	112	111	107	107	108	106	106	99	96	117	112

Attenuation for hall exhaust assumed to be as follows as supplied from a similar project:

Description	Insertion Loss (dB) per Octave Band (Hz)								
	31.5	63	125	250	500	1000	2000	4000	8000
Attenuator Performance 3 m Length, 25 % Free Area <sup>1</sup>	12	21	37	52	55	55	55	55	47

<sup>1</sup> Data taken from an alternative supplier on a similar project.

*Note 3* L<sub>w</sub> level per m<sup>2</sup>. Based on the ‘L<sub>p</sub> Level in Hall’ stated in Note 2 and the assumption that the roof offers the following sound reduction performance (as advised from a similar project).



**Profile Park Power Plant – Environmental Impact Assessment Report**

Description	Insertion Loss (dB) per Octave Band (Hz)								
	31.5	63	125	250	500	1000	2000	4000	8000
Walls	37	43	42	45	53	60	65	70	70
Roof	35	41	39	43	51	57	62	67	67

Example wall and roof constructions capable of achieving the performance specifications outlined in **Table 3** are:

- Walls: 215 mm thick solid concrete block
- Roof: 250 mm thick hollowcore concrete planks

*Note 4* 12 units in total. Overall L<sub>w</sub> level supplied.

*Note 5* 80dB(A) at 1m advised for building. This level has been assumed and L<sub>w</sub> estimated for walls/roof of building based on areas obtained from drawings to hand.

*Note 6* Overall L<sub>w</sub> level supplied.

*Note 7* 2 units in total. Overall L<sub>w</sub> level supplied.

**11.2.3.12 Modelling Calculation Parameters**

Prediction calculations have been conducted in accordance with ISO 9613: *Acoustics – Attenuation of sound outdoors, Part 2: General method of calculation*, 1996.

In terms of calculation a ground attenuation factor (general method) of 0.8 and no metrological correction were assumed for all calculations. The atmospheric attenuation outlined in Table 11-9 were used for all calculations.

*Table 11-9: Atmospheric Attenuation Assumed for Noise Calculations (dB per km)*

Temp (°C)	% Humidity	Octave Band Centre Frequencies (Hz)							
		63	125	250	500	1k	2k	4k	8k
10	70	0.12	0.41	1.04	1.93	3.66	9.66	32.77	116.88

Additional information relating to the noise model inputs and calculation settings is provided in Appendix 11-2.





Profile Park Power Plant – Environmental Impact Assessment Report




Figure 11-3: 3D Render of Developed Noise Model

**11.2.3.13 Additional Information**

The following noise sensitive locations have been considered as part of this assessment.



Figure 11-4: Noise Assessment Locations



**Profile Park Power Plant – Environmental Impact Assessment Report**
*Table 11-10: Assessment Locations*

NSL Ref.	Description
R01	Two-storey residence to the south of the site on the north side of the Baldonnel Road. This location would be representative of residential accommodation associated with Baldonnel aerodrome on the opposite side of the road.
R02	A number of private residences located to the south west of the site along the southern side of the Baldonnel Road.
R03	
R04	
R05	
R06	Commercial property to the north east of the site.
R07	
R08	Derelict residence located to the north east of the site off the Nangor Road. It is assumed that this property will be demolished in due course and is not considered a noise sensitive residence in terms of this review.
R09	Residence located to the north east of the site. It is assumed that this property will be demolished in due course and is not considered a noise sensitive residence in terms of this review.
R10	Commercial buildings including office space located to the north on the opposite side of the Nagor Road.
R11	
R12	
R13	
R14	A row of dormer bungalows located to the north on the opposite side of the Nangor road beside a service station.
R15	Location representative of the Grangecastle Golf Course.
R16	Façade on nearest commercial building to the south of the proposed power plant.

### 11.3 EXISTING ENVIRONMENT

This section documents the typical background noise levels measured in the vicinity of the noise sensitive locations in closest proximity to the proposed power plant site. Table 11-11 presents the measured noise levels at Locations A, B, C and D.

*Table 11-11: Noise Monitoring Results*

Location	Period	Time	Sound Pressure Level (dB)	
			L <sub>Aeq,15min</sub>	L <sub>AF90,15min</sub>
A	Day	10:31 – 10:46	64	55
		11:52 – 12:07	63	50
		13:06 – 13:21	63	51
		<i>Average</i>	63	52
	Evening	21:34 – 21:49	58	42
	Night	22:55 – 23:10	59	41
		00:12 – 00:27	52	37
<i>Average</i>		57	39	



**Profile Park Power Plant – Environmental Impact Assessment Report**

Location	Period	Time	Sound Pressure Level (dB)	
			L <sub>Aeq,15min</sub>	L <sub>AF90,15min</sub>
B	Day	10:53 – 11:08	54	52
		12:10 – 12:25	52	48
		13:49 – 14:04	51	47
		<i>Average</i>	52	49
	Evening	21:56 – 22:09	45	42
	Night	23:15 – 23:30	44	41
		00:31 – 00:46	42	40
<i>Average</i>		43	40	
C	Day	11:14 – 11:29	49	46
		12:29 – 12:44	48	45
		13:31 – 13:46	51	45
		<i>Average</i>	50	45
	Evening	22:14 – 22:29	42	40
	Night	23:32 – 23:47	42	39
		00:48 – 01:03	40	37
<i>Average</i>		41	38	
D	Day	11:32 – 11:47	46	45
		12:47 – 13:03	45	43
		14:07 – 14:23	45	42
		<i>Average</i>	45	43
	Evening	22:32 – 22:47	40	38
	Night	23:50 – 00:05	40	37
		01:06 – 01:21	40	37
<i>Average</i>		40	37	

Note 1 Average L<sub>Aeq</sub> are logarithmic averages, Average L<sub>A90</sub> values are arithmetic averages.

Table 11-12 presents a typical L<sub>90</sub> spectrum noise level that is assumed at the nearest noise sensitive locations during night-time period:

Table 11-12: Typical Background Noise Spectrum Assumed

Location	L <sub>90</sub> Spectrum – Sound Pressure Level (dB) per Octave Band Centre Frequency (Hz)								
	31.5	63	125	250	500	1000	2000	4000	8000
A	54	50	39	34	36	36	25	15	12
B	53	55	43	38	37	36	26	13	12
C	50	47	41	35	34	34	23	14	14
D	50	48	39	33	34	34	21	11	12

## 11.4 ASSESSMENT OF SIGNIFICANT EFFECTS

### 11.4.1 DO NOTHING EFFECTS

If the proposed power plant is not progressed the existing noise environment will remain largely unchanged. Traffic noise is currently a significant noise source in the vicinity of road networks



## Profile Park Power Plant – Environmental Impact Assessment Report

---

in the area. In the absence of the proposed power plant increases in traffic volumes on the local road network would be expected over time and would likely result in slight increases in the overall ambient and background noise levels in the area.

### *11.4.2 POTENTIAL EFFECTS – CONSTRUCTION PHASE*

Construction noise prediction calculations have been conducted using the methodology outlined in Section 11.2.3.7. The noise levels referred to in this section are indicative only and are intended to demonstrate that it will be possible for the contractor to comply with current best practice guidance. The predicted “worst case” levels are expected to occur for only short periods of time at a very limited number of properties. Construction noise levels will be lower than these levels for most of the time at most properties in the vicinity of the proposed power plant.

#### *11.4.2.1 General Construction*

##### Noise

It is predicted that the construction programme will create typical construction activity related noise on site. During the construction phase of the proposed power plant, a variety of items of plant will be in use, such as excavators, lifting equipment, dumper trucks, compressors and generators.

The proposed general construction hours are 07:00 to 18:00hrs, Monday to Friday and 08:00 to 14:00hrs on Saturdays. Occasional weekday evening works may also be required; however evening activities will be significantly reduced in order to manage any associated noise impacts in an appropriate manner and more stringent construction noise criteria will be applicable during any evening works that may be required. As a result, noise emissions from evening activities are expected to be significantly lower than for other general daytime activities.

Due to the nature of daytime activities undertaken on a construction site of this nature, there is potential for generation of significant levels of noise. The flow of vehicular traffic to and from a construction site is also a potential source of relatively high noise levels. The potential for vibration at neighbouring sensitive locations during construction is typically limited to excavation works and lorry movements on uneven road surfaces. Due to the distance of sensitive locations to site works however, there is little likelihood of structural or even cosmetic damage to existing neighbouring dwellings as a result of vibration.

It is possible to predict typical noise levels using guidance set out in BS 5228-1. Table 11-13 outlines typical plant items and associated noise levels that are anticipated for various phases of the construction programme.

For the purposes of the assessment, we have assumed that standard good practice measures for the control of noise from construction sites will be implemented. These issues are commented upon in further detail in the mitigation section of this report.



Table 11-13: Typical Construction Noise Emission Levels

Phase	Item of Plant (BS 5228-1 Ref.)	Construction Noise Level at 10m Distance (dB L <sub>Aeq,1hr</sub> )
1 – Site Preparation including gas and electrical grid trench construction	Pneumatic Breaker (C5.6)	95
	Rock Breaker (C9.12)	85
	Wheeled Loader Lorry (C2 28)	74
	Tracked Semi-Mobile Crusher (C9.14)	90
	Track Excavator (C2 22)	72
	Dozer (C2.13)	78
	Dump Truck (C4.2)	78
2 – Foundations	Large Rotary Bored Piling Rig – Cast In-Situ (C3.14)	83
	Tracked Excavator (C3.24)	74
	Concrete Pump (C3.25)	78
	Compressor (C3 19)	75
	Poker Vibrator (C4 33)	78
3 – Steel Erection	Tower Crane (C4.48)	76
	Sarens SCG 120 Crane	86
	Articulated lorry (C11.10)	77
4 – General Construction	Hand tools	81
	Pneumatic Circular Saw (D7.79)	75
	Internal fit – out	70
	Dozer (C2.13)	78
5 - Landscaping	Dump Truck (C4.2)	78
	Surfacing (D8.25)	68

A number of representative noise sensitive locations have been considered in relation to the proposed power plant as illustrated in Figure 11-4.

Table 11-4 presents the predicted construction noise levels in the vicinity of the site. Calculations have assumed an on time 66% for each item of plant i.e. 8-hours over a 12 hours assessment period.



**Profile Park Power Plant – Environmental Impact Assessment Report**
*Table 11-14: Review of Potential Daytime Construction Noise Levels*

Ref.	Baseline Noise Level dB L <sub>Aeq,1hr</sub>	BS5228-1 Threshold dB L <sub>Aeq,1hr</sub>	Predicted Construction Noise Level for Various Phases (dB L <sub>Aeq,1hr</sub> )				
			Site Preparation	Foundations	Steel Erection	General Construction	Landscaping
R01	45	65	51	41	46	37	28
R02	60	65	47	41	42	39	34
R03	60	65	47	41	42	38	33
R04	60	65	46	40	41	38	33
R05	60	65	42	36	39	35	29
R06 <sup>1</sup>	52	70	53	46	47	43	38
R07 <sup>1</sup>	63	70	41	35	37	32	26
R08	63	70	53	47	47	43	38
R09	52	65	60	53	52	49	44
R10 <sup>1</sup>	63	70	53	47	47	44	39
R11 <sup>1</sup>	63	70	54	47	47	45	40
R12 <sup>1</sup>	63	70	53	47	47	44	39
R13 <sup>1</sup>	63	70	52	46	46	43	38
R14	63	70	51	45	46	43	37
R15	50	65	63	55	54	51	47
R16	50	65	45	38	39	35	31

Note 1 Commercial Property, therefore Threshold of 70 dB L<sub>Aeq,1hr</sub> applies.

Table 11-14 details the baseline noise level measured at the nearest survey noise monitoring location or based on expected ambient noise levels in the vicinity of the location based on proximity to an existing noise source (e.g. road). If the predicted construction noise level is below this value the associated impact is deemed to be 'Not Significant'.

Where the predicted construction noise level is above the baseline noise level but below the stated BS5228-1 threshold value the associated impact is deemed to be between 'Slight' and 'Moderate'. If a predicted noise level is below or equal to the BS5228-1 threshold value, the impact is deemed to be 'Not Significant'. Where the predicted construction noise level is 5dB or more higher than the BS5228-1 threshold value the impact is assumed to be 'Moderate' to 'Significant'.

Note, where a non-residential assessment location is being considered a threshold value of 70 dB L<sub>Aeq,1hr</sub> has been adopted.

Based on the above rationale, and the predicted noise levels presented the assigned impacts are summarised as follows:



**Profile Park Power Plant – Environmental Impact Assessment Report**

*Table 11-15: Review of Potential Daytime Construction Noise Impact*

Ref.	Predicted Construction Noise Impacts for Various Phases				
	Site Preparation	Foundations	Steel Erection	General Construction	Landscaping
R01	Slight	Not Significant	Slight	Not Significant	Not Significant
R02	Not Significant	Not Significant	Not Significant	Not Significant	Not Significant
R03	Not Significant	Not Significant	Not Significant	Not Significant	Not Significant
R04	Not Significant	Not Significant	Not Significant	Not Significant	Not Significant
R05	Not Significant	Not Significant	Not Significant	Not Significant	Not Significant
R06	Not Significant	Not Significant	Not Significant	Not Significant	Not Significant
R07	Not Significant	Not Significant	Not Significant	Not Significant	Not Significant
R08	Not Significant	Not Significant	Not Significant	Not Significant	Not Significant
R09	Slight	Slight	Not Significant	Not Significant	Not Significant
R10	Not Significant	Not Significant	Not Significant	Not Significant	Not Significant
R11	Not Significant	Not Significant	Not Significant	Not Significant	Not Significant
R12	Not Significant	Not Significant	Not Significant	Not Significant	Not Significant
R13	Not Significant	Not Significant	Not Significant	Not Significant	Not Significant
R14	Not Significant	Not Significant	Not Significant	Not Significant	Not Significant
R15	Slight	Slight	Slight	Slight	Not Significant
R16	Not Significant	Not Significant	Not Significant	Not Significant	Not Significant

In the majority of cases, the construction noise impact is Not Significant; in a small number of cases, a Slight impact is predicted.

**Vibration**

Due to the distance of the proposed works from sensitive locations significant vibration effects are not expected.

**Description of Effects**

With respect to the EPA’s criteria for description of effects, the potential worst-case associated effects at the nearest noise sensitive locations associated with this aspect of the construction phase are described below.

<i>Quality</i>	<i>Significance</i>	<i>Duration</i>
Negative	Slight	Short-term

The above effects should be considered in terms that the effect is variable and that this assessment considers the locations of the greatest potential impact.

**11.4.2.2 Construction Traffic**

This section has been prepared in order to review potential noise impacts associated with construction traffic on the local road network. Chapter 16 of this EIAR presents an assessment





**Profile Park Power Plant – Environmental Impact Assessment Report**

of traffic and transportation and reference has been made to this chapter to inform the following discussion.

In terms of the additional construction traffic on local roads that will be generated as a result of the proposed power plant the following comment is presented: Considering that in order to increase traffic noise levels by 1dB traffic volumes would need to increase by the order of 25%. It is considered that additional traffic introduced onto the local road network due to the construction phase associated with various phases of the development will not result in a significant noise impact.

**Vibration**

Construction vehicle movements are not expected as a significant source of vibration along the existing road networks.

**Description of Effects**

With respect to the EPA’s criteria for description of effects, the potential worst-case associated effects at the nearest noise sensitive locations are described below.

<i>Quality</i>	<i>Significance</i>	<i>Duration</i>
Negative	Not Significant	Short-term

**11.4.3 POTENTIAL EFFECTS – OPERATIONAL PHASE**

**11.4.3.1 Assessment of Building Services Noise**

Table 11-16 presents the predicted noise at all assessment locations considering the impact of the Proposed power plant.

*Table 11-16: Predicted Noise Levels*

Ref.	Sound Pressure (dB) per Octave Band Centre Freq (Hz)									dB	dB(A)
	31.5	63	125	250	500	1k	2k	4k	8k		
R01	55	50	39	34	29	33	29	16	--	54	36
R02	53	48	37	32	28	32	26	8	--	52	35
R03	53	48	36	32	28	32	26	7	--	52	35
R04	52	48	36	31	27	32	26	7	--	52	34
R05	51	46	35	30	26	29	23	2	--	50	32
R06	57	50	40	37	30	36	18	6	--	56	38
R07	54	46	34	29	21	22	11	--	--	53	27
R08	57	50	40	37	31	36	18	6	--	56	38
R09	62	55	46	43	37	43	31	21	--	61	45
R10	57	51	41	38	32	38	30	16	--	56	40
R11	57	51	41	38	33	38	30	17	--	56	40
R12	56	51	41	38	33	37	29	15	--	56	39
R13	56	51	41	37	33	37	27	11	--	56	39



**Profile Park Power Plant – Environmental Impact Assessment Report**

Ref.	Sound Pressure (dB) per Octave Band Centre Freq (Hz)									dB	dB(A)
	31.5	63	125	250	500	1k	2k	4k	8k		
R14	55	50	40	37	32	36	26	9	--	55	38
R15	66	60	52	45	40	44	38	31	19	65	47
R16	54	50	37	31	27	49	25	18	--	55	49

A noise contour for day to day operation of the proposed power plant has been presented in Appendix 11-3. Table 11-17 compares the predicted noise at all assessment locations against the adopted criteria.

*Table 11-17: Review of Overall Noise Levels*

Ref.	Predicted Noise Level dB(A)	Criterion dB L <sub>Aeq,15min</sub>	Excess (dB)
R01	36	37	--
R02	35	37	--
R03	35	37	--
R04	34	37	--
R05	32	37	--
R06	38	55	--
R07	27	55	--
R08	38	55	--
R09	45	55	--
R10	40	55	--
R11	40	55	--
R12	39	55	--
R13	39	55	--
R14	38	39	--
R15	47	55	--
R16	49	55	--

The updated predicted noise levels satisfy the relevant noise criteria adopted in this assessment.

Table 11-18 reviews the predicted low-frequency noise at each location vs. the nominal limits recommended in relation to this issue in Table 11-6. Review of the predictions indicate that the proposed low frequency noise limits are substantively complied with.



**Profile Park Power Plant – Environmental Impact Assessment Report**
*Table 11-18: Review of Low Frequency Noise*

Ref.	Predicted Noise Level dB(A)	Criterion dB $L_{Aeq,15min}$	Excess (dB)
<i>Limit</i>	56	50	40
R01	55	50	39
Excess	--	--	--
R02	53	48	37
Excess	--	--	--
R03	53	48	36
Excess	--	--	--
R04	52	48	36
Excess	--	--	--
R05	51	46	35
Excess	--	--	--
R14	55	50	40
Excess	--	--	--

Table 11-19, 11-20 and 11-21 present the predicted changes in noise level associated with the development at the nearest residential noise sensitive locations to the site.

*Table 11-19: Review of Predicted Changes in Existing Noise Levels – Day*

Ref.	Daytime (07:00 – 19:00 hrs)				
	Predicted dB $L_{Aeq,T}$	Background Level dB $L_{A90,T}$	Cumulative Noise Level (dB(A))	Change in Noise Level (dB)	EPA Glossary of Impacts
R01	36	43	44	+1	Not Significant
R02	35	52	52	0	Not Significant
R03	35	52	52	0	Not Significant
R04	34	52	52	0	Not Significant
R05	32	52	52	0	Not Significant
R14	38	52	52	0	Not Significant

*Table 11-20: Review of Predicted Changes in Existing Noise Levels – Evening*

Ref.	Evening (19:00 – 23:00 hrs)				
	Predicted dB $L_{Aeq,T}$	Background Level dB $L_{A90,T}$	Cumulative Noise Level (dB(A))	Change in Noise Level (dB)	EPA Glossary of Impacts
R01	36	38	40	2	Not Significant
R02	35	42	43	1	Not Significant
R03	35	42	43	1	Not Significant
R04	34	42	43	1	Not Significant
R05	32	42	42	0	Not Significant
R14	38	42	44	2	Not Significant



**Profile Park Power Plant – Environmental Impact Assessment Report**

*Table 11-21: Review of Predicted Changes in Existing Noise Levels – Night*

Ref.	Night (23:00 – 07:00 hrs)				
	Predicted dB LAeq,T	Background Level dB LA90,T	Cumulative Noise Level (dB(A))	Change in Noise Level (dB)	EPA Glossary of Impacts
R01	36	37	40	3	Slight
R02	35	39	41	2	Not Significant
R03	35	39	41	2	Not Significant
R04	34	39	40	1	Not Significant
R05	32	39	40	1	Not Significant
R14	38	39	42	3	Slight

Review of the predicted increases in noise level at the nearest residential noise sensitive locations conclude that the associated impact is ‘Not Significant’ at all locations for daytime and evening periods. During night-time periods the predicted impact is Not Significant at all locations with the exception of R01 and R14 where a Slight impact is predicted.

**Description of Effects**

With respect to the EPA’s criteria for description of effects, the potential worst-case associated effects at the nearest noise sensitive locations associated with operation of the power plant is described below.

<i>Quality</i>	<i>Significance</i>	<i>Duration</i>
Negative	Slight	Long-term

The above effects should be considered in terms that the effect is variable and that this assessment considers the locations of the greatest potential impact.

For the majority of locations assessed here the effect of the operational turbines can be considered to be as follows:

<i>Quality</i>	<i>Significance</i>	<i>Duration</i>
Negative	Not Significant	Long-term

There are no expected sources of vibration associated with the operational phase of the proposed power plant. In relation to vibration the associated effect is summarised as follows:

<i>Quality</i>	<i>Significance</i>	<i>Duration</i>
Negative	Imperceptible	Long-term



**Profile Park Power Plant – Environmental Impact Assessment Report**

**11.4.3.2 Additional Road Traffic**

In terms of the additional traffic on local roads that will be generated as a result of this development the following comment is presented: Considering that in order to increase traffic noise levels by 1dB traffic volumes would need to increase by the order of 25% it is considered that additional traffic introduced onto the local road network due to this development will not result in a significant noise impact. The resultant noise impact is neutral, imperceptible and long-term.

**Description of Effects**

With respect to the EPA’s criteria for description of effects, the potential worst-case associated effects at the nearest noise sensitive locations associated with operation of the additional road traffic is described below.

<i>Quality</i>	<i>Significance</i>	<i>Duration</i>
Negative	Imperceptible	Long-term

**11.4.3.3 Decommissioning Phase**

In relation to the decommissioning phase, similar overall noise levels as those calculated for the construction phase would be expected, as similar tools and equipment will be used and a similar noise and vibration impact as outlined previously would be applicable in this instance.

**11.4.3.4 Cumulative Impacts**

The environmental noise survey takes account of noise emissions from existing developments including nearby data centres. It was noted that the existing ambient noise levels in the area were dominated primarily by road traffic on the surrounding road network.

The noise criteria proposed for new building services plant items has been derived with consideration of existing site noise emissions levels to ensure that cumulative noise emissions do not exceed the relevant noise criteria.

The potential cumulative noise emissions from the proposed power plant, DUB69 and Cyrus One Data Centre and Microsoft have been considered. Reference is made to Section 10 of the Cyrus One EIAR, Section 10 of the DUB69 EIAR and Section 8.0 of the Microsoft DUB14/15 EIAR which present noise predictions to nearby shared residential receptors.

The closest shared receptors to the two neighbouring sites are the receivers R02 and R14. Table 11-22 presents the predicted cumulative noise levels to these two receivers and highlights the predicted increase in noise level.



Table 11-22: Assessment of Cumulative Noise

Ref.	Noise Level (dB L <sub>Aeq,T</sub> )				Cumulative dB(A)	Change in Noise Level (dB)
	Profile Park	Cyrus One	DUB69	Existing (Night)		
R02 <sub>A</sub>	35	12	31	37	40	+3
R14 <sub>B</sub>	38	12	30	39	42	+3

Note A NSL R8 in DUB69 assessment R7 (extrapolated) in Cyrus One assessment.

Note B NSL R14 (extrapolated) in DUB69 assessment R7 (extrapolated) in Cyrus One assessment.

Review of the predicted increases in noise level at the nearest residential noise sensitive locations conclude that the associated cumulative impact is ‘Slight’ for night-time periods. The predicted impact is Not Significant at for day and evening periods.

## 11.5 MITIGATION MEASURES

The assessment of potential impact has demonstrated that the proposed power plant is expected to comply with the identified criteria for both the construction, operational and decommissioning phases. However, to ameliorate any noise and vibration effects, a schedule of noise control measures has been formulated for both construction/decommissioning and operational phases.

### 11.5.1 CONSTRUCTION AND DECOMMISSIONING PHASES

The comments in this section relate primarily to the construction phase, but are apply equally to the decommissioning phase:

Regarding construction/decommissioning activities, reference shall be made to BS 5228-1:2009+A1:2014 *Code of practice for noise and vibration control on construction and open sites – Noise*, which offers detailed guidance on the control of noise and vibration from construction activities. It is proposed that various practices be adopted during construction as required, including the following:

- limiting the hours during which site activities likely to create high levels of noise or vibration are permitted;
- establishing channels of communication between the contractor/developer, Local Authority and residents;
- appointing a site representative responsible for matters relating to noise and vibration;
- monitoring typical levels of noise and vibration during critical periods and at sensitive locations; and
- keeping the surface of the site access roads even to mitigate the potential for vibration from lorries.

Furthermore, a variety of practicable noise control measures will be employed. These include:

- selection of plant with low inherent potential for generation of noise and/ or vibration;



## Profile Park Power Plant – Environmental Impact Assessment Report

---

- placing of noisy / vibratory plant as far away from sensitive properties as permitted by site constraints, and
- regular maintenance and servicing of plant items.

### 11.5.1.1 Noise

The contract documents shall specify that the Contractor undertaking the construction of the works will be obliged to take specific noise abatement measures when deemed necessary to comply with the recommendations of BS 5228-1:2009+A1:2014 *Code of practice for noise and vibration control on construction and open sites – Noise*. The following list of measures will be considered, where necessary, to ensure compliance with the relevant construction noise criteria:

- No plant used on site will be permitted to cause an on-going public nuisance due to noise.
- The best means practicable, including proper maintenance of plant, will be employed to minimise the noise produced by on site operations.
- All vehicles and mechanical plant will be fitted with effective exhaust silencers and maintained in good working order for the duration of the contract.
- Compressors will be attenuated models, fitted with properly lined and sealed acoustic covers which will be kept closed whenever the machines are in use and all ancillary pneumatic tools shall be fitted with suitable silencers.
- Machinery that is used intermittently will be shut down or throttled back to a minimum during periods when not in use.
- Any plant, such as generators or pumps, which is required to operate before 07:00hrs or after 19:00hrs will be surrounded by an acoustic enclosure or portable screen.
- During the construction programme, supervision of the works will include ensuring compliance with the limits detailed in Table 11-1 using methods outlined in BS 5228-1:2009+A1:2014 *Code of practice for noise and vibration control on construction and open sites – Noise*.
- The hours of construction activity will be limited to avoid unsociable hours where possible. Construction operations shall generally be restricted to between 7:00hrs and 19:00hrs weekdays and between 7:00hrs and 19:00hrs on Saturdays. However, to ensure that optimal use is made of good weather period or at critical periods within the programme (i.e. concrete pours) or to accommodate delivery of large turbine component along public routes it could be necessary on occasion to work outside of these hours. Any such out of hours working will be agreed in advance with the local Planning Authority.

### 11.5.1.2 Vibration

Vibration associated with construction activities will be limited to the values set out in Table 11-3. It should be noted that these limits are not absolute but provide guidance as to magnitudes of vibration that are very unlikely to cause cosmetic damage.

On review of the likely vibration levels associated with construction activities, it is concluded that the construction of the proposed power plant is not expected to give rise to vibration that is either significantly intrusive or capable of giving rise to structural or cosmetic damage to buildings.



## Profile Park Power Plant – Environmental Impact Assessment Report

---

In the unlikely event of vibration levels giving rise to human discomfort, in order to minimise such impacts, the following measures shall be implemented during the construction period:

- A clear communication programme will be established to inform closest building occupants in advance of any potential intrusive works which may give rise to vibration levels likely to exceed perceptible levels. The nature and duration of the works will be clearly set out in all communication circulars.
- Alternative less intensive working methods and/or plant items shall be employed, where feasible.
- Appropriate vibration isolation shall be applied to plant, where feasible.
- Cut off trenches to isolate the vibration transmission path shall be installed where required.
- Monitoring will be undertaken at identified sensitive buildings, where proposed works have the potential to be at or exceed the vibration limit values.

### **11.5.2 OPERATIONAL PHASE**

Noise from external plant will be minimised by the following measures:

- Purchasing low noise generating equipment, and;
- Incorporating appropriately specified in line attenuators for stacks and exhausts where necessary.

With due consideration as part of the detailed design process, this approach will result in the site operating well within the constraints of the best practice guidance noise limits that have been adopted as part of this detailed assessment.

### **11.5.3 DECOMMISSIONING PHASE**

The mitigation measures that will be considered in relation to any decommissioning of the site are the same as those proposed for the construction phase of the development, i.e. as per Section 12.5.1.

### **11.5.4 MONITORING**

#### **11.5.4.1 Construction Phase**

Noise and vibration monitoring is proposed in accordance with the guidance contained in *British Standard BS5528* during the construction phase.

#### **11.5.4.2 Operational Phase**

As part of the EPA IED license that will be applicable to the site annual noise monitoring will be required to ensure noise emissions comply with relevant criteria.

## **11.6 RESIDUAL EFFECTS**

This section summarises the likely residual noise and vibration effects associated with the proposed power plant following the implementation of mitigation measures.





**Profile Park Power Plant – Environmental Impact Assessment Report**

**11.6.1 CONSTRUCTION / DECOMMISSIONING PHASES**

During the construction phase of the project there will be some effect on nearby noise sensitive properties due to noise emissions from site traffic and other construction activities. However, given the distances between the main construction works and nearby noise sensitive properties and the fact that the construction phase of the development is temporary in nature, it is expected that the various noise sources will not be excessively intrusive. Furthermore, the application of binding noise limits and hours of operation, along with implementation of appropriate noise and vibration control measures, will ensure that noise and vibration effect is kept to a minimum.

With respect to the EPA’s criteria for description of effects, in terms of these construction activities, the potential worst-case associated effects at the nearest noise sensitive locations associated with the various elements of the construction phase are described below.

The effects below should be considered in terms that the effect is variable and that this assessment considers the locations of the greatest potential impact.

**11.6.1.1 General Construction**

Noise Assessment

<i>Quality</i>	<i>Significance</i>	<i>Duration</i>
Negative	Slight	Short-term

Vibration Assessment

<i>Quality</i>	<i>Significance</i>	<i>Duration</i>
Negative	Not Significant	Momentary

**11.6.1.2 Construction Traffic**

The predicted residual construction traffic effects during the construction phase are summarised as follows:

Noise Assessment

<i>Quality</i>	<i>Significance</i>	<i>Duration</i>
Negative	Not Significant	Short-term

Vibration Assessment

<i>Quality</i>	<i>Significance</i>	<i>Duration</i>
Negative	Not Significant	Momentary



**Profile Park Power Plant – Environmental Impact Assessment Report**

**11.6.2 OPERATIONAL PHASE**

**11.6.2.1 Building Services Noise**

The predicted residual operational turbine noise effects are summarised as follows at the closest noise sensitive locations to the site:

<i>Quality</i>	<i>Significance</i>	<i>Duration</i>
Negative	Slight	Long-term

The above effects should be considered in terms that the effect is variable and that this assessment considers the locations of the greatest potential impact.

For the majority of locations assessed here the effect of the operational power plant can be considered to be as follows:

<i>Quality</i>	<i>Significance</i>	<i>Duration</i>
Negative	Not Significant	Long-term

In terms of vibration, the effect of the operational site is as follows:

<i>Quality</i>	<i>Significance</i>	<i>Duration</i>
Negative	Not Significant	Long-term

**11.6.2.2 Cumulative Effects**

Cumulative assessment has been considered here with due consideration of the proposed power plant in combination with any existing permitted and proposed developments in the wider study area. It has been predicted that the cumulative effects are Not Significant during daytime and evening periods and Slight during night time periods.

**11.7 CONCLUSION**

When considering a development of this nature, the potential noise and vibration effects on the surroundings must be considered for two stages: the short-term construction and the long-term operational phase.

The assessment of construction noise and vibration and has been conducted in accordance best practice guidance contained in *BS 5228-1:2009+A1:2014 Code of practice for noise and vibration control on construction and open sites – Noise* and *BS 5228-2:2009+A1:2014 Code of practice for noise and vibration control on construction and open sites – Vibration*. Subject to good working practice as recommended in the EIAR, noise associated with the construction phase is not expected to exceed the recommended limit values. The associated noise and vibration are not expected to cause any significant effects.



## Profile Park Power Plant – Environmental Impact Assessment Report

Based on detailed information on the site layout, plant noise emission levels, noise levels have been predicted at NSLs. The predicted operational noise levels will be within best practice noise limits; therefore, it is not considered that a significant effect is associated with the development.

No significant vibration effects are associated with the operation of the site.

### 11.8 REFERENCES

- EPA Draft Guidelines on the information to be contained in Environmental Impact Assessment Reports (EIA Reports) (2017) and draft revised Guidelines on information to be contained in Environmental Impact Statements; and Advice Notes for preparing EIS (2015).
- Draft ‘*Guidelines for Noise Impact Assessment*’ produced by the Institute of Acoustics/Institute of Environmental Management and Assessment Working Party.
- *British Standard BS 5228 – 1: 2009+A1:2014: Code of practice for noise and vibration control on construction and open sites – Noise.*
- Transport Infrastructure Ireland (TII) publication *Guidelines for the Treatment of Noise and Vibration in National Road Schemes.*
- British Standard BS 7385: 1993: *Evaluation and measurement for vibration in buildings Part 2: Guide to damage levels from ground borne vibration.*
- British Standard BS 5228-2: 2009+A1:2014: *Code of practice for noise and vibration control on construction and open sites – Vibration.*
- BS 4142:2014: *Methods for rating and assessing industrial and commercial sound.*
- BS 8233:2014: *Guidance on sound insulation and noise reduction for buildings.*
- Environmental Protection Agencies *Guidance Note for Noise: Licence Applications, Surveys and Assessments in Relation to Scheduled Activities (NG4)* (January 2016).
- ISO 1996-2:2017 *Acoustics - Description, measurement and assessment of environmental noise – Part 2: Determination of environmental noise levels.*
- British Standard *BS 6472 (1992): Guide to Evaluation of human exposure to vibration in buildings (1Hz to 80Hz).*
- ISO 9613 (1996): *Acoustics – Attenuation of sound outdoors – Part 2: General method of calculation.*
- *Calculation of Road Traffic Noise (CRTN)* issued by the Department of Transport in 1988.
- BS EN 1793-1:1998: *Road traffic noise reducing devices – Test method for determining the acoustic performance – Part 1: Intrinsic characteristics of sound absorption*
- BS EN 1793-2:1998: *Road traffic noise reducing devices – Test method for determining the acoustic performance – Part 2: Intrinsic characteristics of airborne sound insulation.*
- BS EN 1794-1:2003: *Road traffic noise reducing devices. Non-acoustic performance. Mechanical performance and stability requirements*
- BS EN 1794-2:2003: *Road traffic noise reducing devices. Non-acoustic performance. General safety and environmental requirements.*

