

An Rannóg Talamhúsáide, Pleanála agus Iompair
Land Use, Planning & Transportation Department
Telephone: 01 4149000 Fax: 01 4149104 Email: planning.dept@sdublincoco.ie

Joe Fallon Design
1A, Ryland Street
Bunclody
Co. Wexford

PLANNING & DEVELOPMENT ACT, 2000 (as amended) AND PLANNING REGULATIONS THEREUNDER

Decision Order Number: 1194	Date of Decision: 06-Sep-2021
Register Reference: SD21B/0392	Registration Date: 12-Jul-2021

Applicant: John & Roisin Bagnall

Development: Single storey flat roof porch extension of 4.5sq.m to the front; single storey flat roof extension of 7sq.m and renovation to the rear with 3 rooflights; conversion of existing hip roof to a dutch gable roof; conversion of attic space to storage space with 1 rooflight to the front and dormer window to the rear and all associated site works.

Location: 179, Templeville Road, Dublin 6w

Application Type: Permission

Dear Sir /Madam,

With reference to your planning application, received on 12-Jul-2021 in connection with the above, I wish to inform you that before the application can be considered under Section 33 of the Planning & Development Act 2000, six copies of the following **ADDITIONAL INFORMATION** must be submitted.

1. (1) There are no soil percolation test results, design calculations or dimensions submitted for the proposed soakaway. The applicant is requested to submit a report showing site specific soil percolation test results and design calculations for the proposed soakaway in accordance with BRE Digest 365 – Soakaway Design.
(2) The applicant is requested to submit a revised drawing showing plan & cross-sectional views, dimensions, and location of proposed soakaway. Any proposed soakaway shall be located fully within the curtilage of the property and shall be:
 - (i) At least 5m from any building, public sewer, road boundary or structure.
 - (ii) Generally, not within 3m of the boundary of the adjoining property.
 - (iii) Not in such a position that the ground below foundations is likely to be adversely affected.

- (iv) 10m from any sewage treatment percolation area and from any watercourse / floodplain.
(v) Soakaways must include an overflow connection to the surface water drainage network.
(3) The applicant shall include Water Butts as part of Sustainable Drainage Systems (SuDS) measures for the proposed development.
2. (1) It is unclear where the proposed existing foul drainage system on site connects to the public wastewater drainage network. The applicant is requested to submit a drawing showing existing and proposed foul water drainage layouts up to and including the point of connection to the public foul water sewer. The drawing shall include the location of all AJs, manholes, pipe size, material type and direction of flow. The drawing shall clearly show that the foul and surface water systems are discharging to separate pipe networks. Maps of the public watermains and Wastewater drainage networks may be obtained, if available, for required locations in by emailing: datarequests@water.ie.
(2) The applicant is requested to show the location of existing and proposed foul manholes/access points on a drawing. The applicant is required to demonstrate how access will be maintained to the existing private foul drain after development has taken place. All proposals in this regard must comply with the building regulations technical guidance document Part H-Drainage and Wastewater disposal.
(3) All works are to comply with the Irish Water Standard Details & Code of Practice for Water Infrastructure.

NOTE: The applicant should note that any submission made in response to the above will be examined and MAY be deemed to be SIGNIFICANT ADDITIONAL INFORMATION by the Planning Authority. In this event the applicant(s) will be subsequently notified and requested to publish a notice in an approved newspaper and erect or fix a site notice on the land or structure to which the further information relates and to submit copies of the both the newspaper and site notices to the Planning Authority in accordance with Article 35 (1) (a) and (b) of the Planning and Development Regulations 2001 (as amended).

Note: The applicant must submit the Further Information within **6 months** of the **date of decision**. If the information is not received within this period the planning authority shall declare the application to be withdrawn.

Please ensure that your reply to this Request for Additional Information is accompanied by a covering letter marked "ADDITIONAL INFORMATION" and that the Planning Register Reference Number given above is quoted on the covering letter.

Signed on behalf of South Dublin County Council

Register Reference: SD21B/0392

Date: 07-Sep-2021

Yours faithfully,


for **Senior Planner**