Water Services Planning Report

Register Reference No.: SD21B/0410

Development: Domestic extension and alterations to existing two-

storey semi-detached dwelling comprising of single and two storey extensions to rear; two storey extension to side; elevation changes; modifications to existing house; new rooflights to front roof; widen existing entrance

gateway and all ancillary works.

Location: 9, Orchardstown Villas, Dublin 14

Application Type: Permission **Report Date:** 26th August 2021

Surface Water Report:

Further Information Required:

- 1.1 There are no soil percolation test results, design calculations or dimensions submitted for the proposed soakaway. The applicant is required to submit a report showing site specific soil percolation test results and design calculations for the proposed soakaway in accordance with BRE Digest 365 Soakaway Design.
- **1.2** The applicant is required to submit a revised drawing showing plan & cross-sectional views, dimensions, and location of proposed soakaway. Any proposed soakaway shall be located fully within the curtilage of the property and shall be:
- i) At least 5m from any building, public sewer, road boundary or structure.
- ii) Generally, not within 3m of the boundary of the adjoining property.
- iii) Not in such a position that the ground below foundations is likely to be adversely affected.
- iv) 10m from any sewage treatment percolation area and from any watercourse / floodplain.
- v) Soakaways must include an overflow connection to the surface water drainage network.
- **1.3** The applicant shall include Water Butts as part of additional Sustainable Drainage Systems (SuDS) measures for the proposed development.
- All works shall comply with the Building Regulations -Technical guidance document- Part H Drainage and Wastewater disposal
- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.

Water Services Planning Report

Dublin Regional Code of Practice for Drainage Works.

Brian Harkin SEE

• All works for this development shall comply with the requirements of the Greater

Flood Risk Report:

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed:

Ronan Toft AE

Endorsed:

Date:

Date: