Water Services Planning Report

Register Reference No.: SD21B/0419

Development: Ground floor extension to rear and side of existing

dwelling; internal modifications and associated site

works.

Location: 19, Muckross Grove, Dublin 12

Application Type: Permission

Report Date: 31st August 2021

Surface Water Report:

Further Information Required:

1.1 The applicant shall include further SuDS (Sustainable Drainage Systems) such as soakaways for the proposed development.

Where it is possible to include a soakaway/infiltration systems the applicant shall submit the following:

- a.) a report showing site specific soil percolation test results and design calculations for the proposed soakaway in accordance with BRE Digest 365 – Soakaway Design.
- b.) a drawing showing plan & cross-sectional views, dimensions, and location of proposed soakaway. Any proposed soakaway shall be located fully within the curtilage of the property and shall be:
 - i.) At least 5m from any building, public sewer, road boundary or structure.
 - ii.) Generally, not within 3m of the boundary of the adjoining property.
 - iii.) Not in such a position that the ground below foundations is likely to be adversely affected.
 - iv.) 10m from any sewage treatment percolation area and from any watercourse / floodplain.
 - v.) Soakaways must include an overflow connection to a public surface water sewer.
- All works shall comply with the Building Regulations -Technical guidance document- Part H Drainage and Wastewater disposal
- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
- All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.

Water Services Planning Report

Flood Risk	K Report:		No objection:
Water Report:			Referred to IW
Foul Drain		Referred to IW	
Signed:	Ronan Toft AE	Date: _	
Endorsed:	Brian Harkin SEE	Date: _	