

**Irish Water's Statutory
Response to**

South Dublin

Planning Authority



Uisce Éireann
Bosca OP 6000
Baile Átha Cliath 1
Éire

Irish Water
PO Box 6000
Dublin 1
Ireland

T: +353 1 89 25000
F: +353 1 89 25001
www.water.ie

Planning Application No.

SD21A/0226

Date Lodged with Planning Authority:

13.08.2021

Development:

Partial change of use of the ground floor of an existing dwelling to a childcare facility; proposed ground floor extension to form part of the childcare facility; new side entrance; proposed rear extension to the existing ground floor measuring 12sq.m; Internal alterations to include proposed accessible wc and minor demolition to accommodate new extension; all associated ancillary site works.

Location :

4, Griffeen Glen Drive, Griffeen Glen, Lucan, Co. Dublin

IW Recommendation: **No Objection**

IW Observations:

Irish Water requests that any grant of permission will be conditioned as follows:

1. The applicant shall sign a connection agreement with Irish Water prior to the commencement of the development and adhere to the standards and conditions set out in that agreement.
2. All development shall be carried out in compliance with Irish Water Standards codes and practices.
3. Any proposals by the applicant to divert or build over existing water or wastewater services shall be submitted to Irish Water for written approval prior to works commencing.
4. Separation distances between the existing Irish Water assets and proposed structures, other services, trees, etc. have to be in accordance with the Irish Water Codes of Practice and Standard Details.

Reason: To ensure adequate provision of water and wastewater facilities.

Signed on Behalf of Irish Water: **Maria O'Dwyer**

Date: **10/09/2021**

