

Water Services Planning Report

Register Reference No.: SD21B/0437
Development: Construction of a ground floor extension in the front courtyard; first floor pitched roof re-design consisting of 2 bedrooms and a ground floor extension to the rear of the house with all associated site works.

Location: 32, The Dale, Kingswood Heights, Dublin 24

Application Type: Permission
Report Date: 3rd September 2021

Surface Water Report:

Further Information Required:

- 1.1** The applicant has not proposed any SuDS (Sustainable Drainage Systems) features for the proposed development. The applicant is required to submit a drawing in plan and cross sectional views clearly showing proposed Sustainable Drainage Systems (SuDS) features for the development.
- All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
 - All works shall comply with the Building Regulations -Technical guidance document- Part H Drainage and Wastewater disposal

Flood Risk Report:

No objection:

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Adam Adderley McCabe GE

Date: _____

Endorsed: _____
Brian Harkin SEE

Date: _____