

# Water Services Planning Report

**Register Reference No.:** SD21B/0442  
**Development:** Remove existing roof on single storey extension to rear of existing dwelling; demolish garage in rear garden; erect single storey granny flat in rear garden and re-roof existing single storey extension to rear; all ancillary site works.  
**Location:** 69, Castle Close, Clondalkin, Dublin 22  
**Application Type:** Permission  
**Report Date:** 14<sup>th</sup> September 2021

---

## Surface Water Report:

**No objection subject to:**

1.1 Include water butts as part of SuDS (Sustainable Drainage Systems) for the proposed development

- All works shall comply with the Building Regulations -Technical guidance document- Part H Drainage and Wastewater disposal
  - The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
  - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
- 

## Flood Risk Report:

**No objection:**

---

## Water Report:

**Referred to IW**

## Foul Drainage Report:

**Referred to IW**

Signed: \_\_\_\_\_  
Ronan Toft AE

Date: \_\_\_\_\_

Endorsed: \_\_\_\_\_  
Brian Harkin SEE

Date: \_\_\_\_\_