

Water Services Planning Report

Register Reference No.: SD21A/0236
Development: Amalgamation of units F2 and F3 (with connecting doors at ground and first floor levels) and its use for warehouse and distribution with ancillary trade counter and showroom at ground and first floor levels; Retention of offices at second floor level which are ancillary to the overall warehouse operation; Retention of all signage and external illumination of the signage.
Location: Units F2 & F3, Weatherwell Business Park, Clondalkin, Dublin 22
Report Date : 27th Sept 2021

Surface Water Report:

No objection subject to:

Flood Risk

No Objection

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
 - All new precast surface water manholes shall have a minimum thickness surround of 150mm Concrete Class B.
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
-

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Brian Harkin SEE.

Date: _____

Endorsed: _____
Chris Galvin SE.

Date: _____