



- NOTES:**
1. ALL DIMENSIONS ARE IN METRES (M) UNLESS NOTED OTHERWISE.
 2. ALL LEVELS ARE IN METRES (M) AND RELATE TO THE ORDNANCE SURVEY DATUM MAJN HEAD.
 3. LIME DOSING LINES - 40MM HDPE CARRYING CALCIUM HYDROXIDE (LIME MLK) AT 1% FOR TREATED WATER PH ADJUSTMENT.
 4. ACID DOSING LINES - 40MM HDPE CARRYING SULPHURIC ACID @ 5% FOR RAW WATER PH ADJUSTMENT.
 5. DE-ALKALISATION PLANT TO BE HOUSED ENTIRELY WITHIN EXISTING BUILDING.

- LEGEND:**
- ROUTE
 - SITE BOUNDARY
 - OWNERSHIP BOUNDARY
 - RIGHT OF WAY
 - PROPOSED LIME DOSING LINE
 - PROPOSED ACID DOSING LINE (OLD WTP)
 - PROPOSED ACID DOSING LINE (NEW WTP)
 - ARCHAEOLOGICAL MONUMENT

REPRODUCED FROM THE ORDNANCE SURVEY BY PERMISSION OF THE GOVERNMENT. LICENCE No. 3-3-34

Ordnance Survey Ireland Licence No. EN 0002721
© Ordnance Survey Ireland / Government of Ireland

REV	DATE	DESCRIPTION	D	C	A
01	28/09/21	Updated following comments	EV	MG	JB

Planning Drawings

COPYRIGHT RESERVED - THIS DRAWING IS NOT TO BE USED FOR A PURPOSE OTHER THAN THAT FOR WHICH IT HAS BEEN ISSUED BY GLAN AGUA LTD. NOR IS IT TO BE COPIED OR REPRODUCED IN ANY MANNER WITHOUT WRITTEN CONSENT.

CLIENT
IRISH WATER
 Colville House,
 24-26 Talbot Street,
 Dublin 1,
 Tel. 1890 278 278 Web. www.water.ie

FINGAL COUNTY COUNCIL,
 County Hall,
 Main Street,
 Swords,
 County Dublin.

PROJECT
LEIXLIP WATER TREATMENT PLANT UPGRADE

GLAN AGUA
 MOTAENGL GROUP
 Glan Agua,
 Railway House,
 Station Road,
 Loughrea,
 Co. Galway,
 IRELAND
 Tel: +353(0)909630301
 Fax: +353(0)909630300
 e-mail: info@glanagua.com
 web: www.glanagua.com

RYAN HANLEY
 CONSULTING ENGINEERS
 1 Colwyn Business Park,
 Dangan, Galway,
 H91A3EF (Head Office).
 Tel: (091) 597116
 Email: info@ryanhaley.ie
 Web: www.ryanhaley.ie
 DUBLIN - GALWAY - CASTLEBAR - CORK

TITLE
PROPOSED LIME DELIVERY ROUTE

SCALE	DRAWN	CHECKED	APPROVED
1:1000	EV	MG	JB
	DATE	DATE	DATE
	28/05/2021	28/05/2021	28/05/2021

DRAWING No.	STATUS	REVISION
11118-RHL-LP2-XX-DR-PL-0020	S2	01

Ordnance Survey Mapping:
3194-16, 3194-17, 3194-21 & 3194-22