



South Dublin County Council
Planning Department
County Hall,
Tallaght
Dublin 24
D24 YNN5

15 October 2021

Re: PLANNING REGISTRATION NO: SD21A/0276

Dear Sir/Madam,

I write with regard to the above planning application by IPUT plc for an amendment to SDCC ref. SD19A/0264 comprising the omission of the 33 permitted Photovoltaic (PV) Solar Panels (53sq.m) to the ancillary office roof and the provision of 400 Photovoltaic (PV) Solar Panels (717sq.m) to the warehouse roof.

Located: Site Q2, Jordanstown Road, Aerodrome Business Park, Collegeland, Rathcoole, Co. Dublin.

Following consultations with our Air Corps colleagues at Casement Aerodrome, The Department of Defence would like to make the following observations:

1. Military Air Traffic Services requests a Glint and Glare Report to assess any potential impact on ATC or flight operations at Casement Aerodrome.
2. Given the proximity to Casement Aerodrome, operation of cranes should be coordinated with Air Corps Air Traffic Services, no later than 28 days before use, contactable at airspaceandobstacles@defenceforces.ie or 01-4037681

Please contact me if you have any queries in this regard.

Yours faithfully,

Sent via e-mail due to Covid19 restrictions

Don Watchorn
Property Management Branch
Department of Defence
Station Road
Newbridge
Co. Kildare W12 AD93
045 492199 don.watchorn@defence.ie