



**LEGEND:**

EXISTING SURFACE WATER SEWER	
EXISTING FOUL WATER SEWER	
EXISTING WATERMAIN	
EXISTING SURFACE WATER MANHOLE	
EXISTING FOUL WATER MANHOLE	
PROPOSED SURFACE WATER SEWER	
PROPOSED FOUL WATER SEWER	
PROPOSED SURFACE WATER MANHOLE	
PROPOSED FOUL WATER MANHOLE	
PROPOSED ATTENUATION TANK IN BASEMENT	
PROPOSED DN80 SURFACE WATER RISING MAIN	
EXTENT OF PROPOSED DEVELOPMENT	

**PROPOSED FOUL MANHOLE**

Name	Cover Level (m)	Diameter (mm)	Easting (m)	Northing (m)	Depth (m)
FMH 1.0	90.500	1200	709469.165	727736.018	2.150
FMH 1.1	90.550	1200	709512.310	727745.543	3.480
FMH 2.0	90.110	1200	709471.649	727775.347	0.620
FMH 2.1	90.110	1200	709486.556	727778.751	0.820

**PROPOSED FOUL PIPES**

Name	US Node	DS Node	Length (m)	US IL (m)	DS IL (m)	Fall (m)	Slope (1:X)	Dia (mm)	US Depth (m)	DS Depth (m)
F1.000	FMH 1.0	FMH 1.1	16.233	88.350	87.070	1.280	12.7	150	2.000	3.330
F2.000	FMH 2.0	FMH 2.1	15.544	89.490	88.290	0.200	77.7	150	0.470	0.670

**PROPOSED STORM MANHOLES**

Name	Cover Level (m)	Diameter (mm)	Easting (m)	Northing (m)	Depth (m)
SMH 1.0	88.035	1200	709490.729	727724.901	1.350
SMH 1.1	88.035	1200	709489.050	727733.317	1.495
SMH 1.2	88.035	1200	709481.695	727735.483	1.624
SMH 1.3	88.035	1200	709482.144	727746.290	1.663
SMH 1.4	88.035	1200	709461.829	727750.071	2.011
SMH 1.5	88.035	1200	709460.563	727743.687	2.121
SMH 1.6	88.035	1200	709458.123	727744.151	2.238
Attenuation Tank & Pump	88.035	1200	709460.329	727754.126	2.298
SMH 2.0	90.140	1500	709476.622	727783.311	1.365
SMH 2.1	90.140	1500	709480.984	727782.945	1.362
SMH 2.2 Outfall	90.400	1200	709453.012	727784.568	1.700
SMH 1.7	91.290	1200	709446.543	727744.269	1.777
SMH 1.8 Outfall	91.290	1200	709444.675	727744.658	1.810

**PROPOSED STORM PIPES**

Name	US Node	DS Node	Length (m)	US IL (m)	DS IL (m)	Fall (m)	Slope (1:X)	Dia (mm)	US Depth (m)	DS Depth (m)
S1.006	SMH 1.6	Attenuation Tank & Pump	10.216	85.797	85.737	0.060	170.0	225	2.013	2.073
S1.005	SMH 1.5	SMH 1.6	2.484	85.914	85.872	0.042	59.1	150	1.971	2.013
S1.004	SMH 1.4	SMH 1.5	6.508	86.024	85.914	0.110	59.2	150	1.861	1.971
S1.003	SMH 1.3	SMH 1.4	20.964	86.372	86.024	0.348	59.4	150	1.513	1.861
S1.002	SMH 1.2	SMH 1.3	10.816	86.411	86.372	0.039	277.3	150	1.474	1.513
S1.001	SMH 1.1	SMH 1.2	7.667	86.540	86.411	0.129	59.4	150	1.345	1.474
S1.000	SMH 1.0	SMH 1.1	8.582	86.685	86.540	0.145	59.2	150	1.200	1.345
S2.001	SMH 2.1	SMH 2.2 Outfall	8.136	88.748	88.700	0.048	170.0	225	1.167	1.215
S2.000	SMH 2.0	SMH 2.1	15.642	88.775	88.748	0.027	586.0	600	0.765	0.792
S1.007	SMH 1.7	SMH 1.8 Outfall	1.908	89.513	89.480	0.033	57.8	225	1.552	1.585

Ordnance Survey Ireland Licence No. EN 0003721  
© Ordnance Survey Ireland/Government of Ireland

© PUNCH Consulting Engineers  
This drawing and any design hereon is the copyright of the Consultants and must not be reproduced without their written consent.  
All drawings remain the property of the Consultants.  
Figured dimensions only to be taken from this drawing.  
Consultants to be informed immediately of any discrepancies before work proceeds.



Rev	Description	By	Date	Rev	Description	By	Date
001	PLANNING ISSUE	IBS	14/05/2021				
002	FI RESPONSE	DAP	04/11/2021				

**PUNCH**  
consulting engineers  
Dublin | Limerick | Cork | Galway | Glasgow  
Carnegie House Library Road,  
Dun Laoghaire, Co. Dublin, A96 C7W7  
t +353 1 271 2200 w punchconsulting.com

Project: GREENHILLS ROAD DEVELOPMENT, TALLAGHT, DUBLIN 24  
Title: PROPOSED GROUND FLOOR DRAINAGE LAYOUT  
Drawn: IBS Date drawn: MARCH 2021  
Project No: 202253-PUNCH-XX-XX-DR-C-0100  
Scale: 1:200  
Drawing Status: AO PLANNING  
New Issue No: C02