## **Water Services Planning Report**

**Register Reference No.:** SD21B/0216 AI

Development: Removal of part of the existing two storey dwelling at

the side and the single storey part at the rear;

construction of a three storey pitched roof extension to the side including roof windows on the front and rear slopes; 2nd floor space will be incorporated within/under the pitched roof slopes; a single storey pitched roof extension to the front; a single storey flat roof extension to the rear including roof windows; miscellaneous works including internal alterations and changes to elevations including to existing and new doors and windows; new window on the existing rear roof slope of the pitched roof; widen pedestrian and vehicular access from the

public footpath and roadway to provide additional off-

street parking.

Location: 80, Glenaulin Green, Dublin 20

Application Type: Permission

**Report Date:** 4<sup>th</sup> November 2021

## **Surface Water Report:**

## No objection subject to:

- **1.1** No buildings shall be located within the public wayleave area for the existing 1.8m surface water sewer to the north of the site.
- **1.2** Include water butts as part of SuDS (Sustainable Drainage System) measures for the proposed development
  - The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
- All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.

Flood Risk Report:	No objection:	
Water Report:	Referred to IW	
Foul Drainage Report:	Referred to IW	

## **Water Services Planning Report**

Signed:		Date:	
	Ronan Toft AE		
Endorsed:		Date:	
	Brian Harkin SEE		