

Comhairle Chontae Atha Cliath Theas

Record of Executive Business and Chief Executive's Order

PR/1493/21

Reg. Reference: SD21A/0044 **Application Date:** 26-Feb-2021
Submission Type: Additional **Registration Date:** 21-Oct-2021
Information

Correspondence Name and Address: John Murphy 2, Birchview Close, Kilnamanagh,
Dublin 24

Proposed Development: Construction of a new two storey clubhouse
(658sq.m); new external activity area (405sq.m); new
boundary fencing for external activity area and all
associated site works adjacent to existing all weather
pitch.

Location: Treepark Road, Kilnamanagh, Dublin 24

Applicant Name: John Murphy, Kilnamanagh AFC

Application Type: Permission

(CS/COS)

Description of Site and Surroundings:

Site Area: 0.76933ha as stated.

Site Description:

The subject site is located at Ned Kelly Park, Treepark Road, Kilnamanagh. The subject site is located to the west of the Greenhills Road, to the north east of Treepark Road and north west of Kilnamanagh Community Centre. The subject site forms part of an overall site (outlined in blue). The subject site is currently in active use and provides local sporting facilities. It is noted that the applicant has stated on their application form that ownership is under license management.

Proposal:

The applicant proposes the following:

- Two storey clubhouse (658sq.m)
- External activity area (405sq.m)
- Boundary fence for external activity area.
- Associated site works adjacent to existing all weather pitch at Treepark Road.

Zoning

This area is under zoning objective 'OS' – *'To preserve and provide for open space and recreational facilities'*.

Consultations:

Surface Water Drainage – **Additional Information** recommended.

Comhairle Chontae Atha Cliath Theas

Record of Executive Business and Chief Executive's Order

Irish Water – **Additional Information** recommended.

Roads Department – **Additional Information** recommended.

Parks Department – **Additional Information** recommended.

E.H.O - acceptable subject to **conditions**.

SEA Sensitivity Screening

Indicates overlap with 'Sites of Geological Interest 2016'.

The overall site overlaps with a Site of Geological Interest known as 'Greenhills Esker', which has a summary description within the County Development Plan, as follows,

'Large ridge comprising sand and gravel'.

In the event of a grant a **note** shall be attached that the applicant should contact the Councils Heritage Officer to ascertain requirements in relation to Site of Geological Interest known as 'Greenhills Esker'.

Submissions/Observations/Representations

None received.

Recent Relevant Planning History

SD17A/0048: Extend existing synthetic surface playing pitch by 15m in length and erect 3.5m high ball stop netting to top of 3m high surround fence and all ancillary site services.

Decision: **GRANT PERMISSION.**

SD12A/0105: Erection of 12.2metre x 3.65metre prefabricated building for use as dressing rooms.

Decision: **GRANT PERMISSION.**

SD08A/0652: Construction of a grass all-weather association football pitch and training area, including drainage, boundary treatment and all associated site works.

Decision: **GRANT PERMISSION.**

SD07A/0463: Construction of 2 no. all-weather synthetic pitch and a natural grass pitch. The larger all-weather synthetic pitch has six flood light columns 12 metres in height and the smaller has 4 no. flood lights columns 12 metres in height. Each all-weather synthetic pitch is surrounded by a 3 meter high fence with a further 3 meter high netting giving an overall height of 6 meters. There is surface water drainage system incorporated beneath the surface of each pitch. The natural grass pitch is an association football pitch with a surface water drainage system incorporated beneath the surface connecting to the existing surface water drainage system and including all associated site works.

Decision: **GRANT PERMISSION.**

Recent Relevant Enforcement History

No recent relevant enforcement history.

Comhairle Chontae Atha Cliath Theas

Record of Executive Business and Chief Executive's Order

ENF. 9871 now closed (pre-APAS).

Pre-Planning Consultation

None indicated.

Relevant Policy in South Dublin County Development Plan (2016-2022)

Housing Policy H6 Sustainable Communities

It is the policy of the Council to support the development of sustainable communities and to ensure that new housing development is carried out in accordance with Government policy in relation to the development of housing and residential communities.

Housing Policy H12 Public Open Space

It is the policy of the Council to ensure that all residential development is served by a clear hierarchy and network of high quality public open spaces that provides for active and passive recreation and enhances the visual character, identity and amenity of the area.

Chapter 3 Community Infrastructure

Policy C1 Community Centres

It is the policy of the Council to ensure that all communities have access to multifunctional community centres that provide a focal point for community activities.

Community Infrastructure Policy 7 – Sports Facilities & Centres

It is the policy of the Council to ensure that all communities are supported by a range of sporting facilities that are fit for purpose, accessible and adaptable.

Community Infrastructure Objective 7:

To support District Level Community Hubs in the Metropolitan Consolidation Towns of Tallaght, Lucan and Clondalkin, to serve the growing population of these settlements and of the County as a whole. Such hubs should incorporate a sports centre with swimming pool, all-weather playing pitches and children's play facilities.

Community Infrastructure Objective 12:

To ensure the provision of adequate indoor and outdoor school sports facilities for all new and existing schools in the County, based on identified need and in line with the final population of the school.

Section 3.13.0 Open Space Management & Use

Policy C12 Open Space

It is the policy of the Council that a hierarchical network of high quality open space is available to those who live, work and visit the County, providing for both passive and active recreation, and that the resource offered by public open spaces, parks and playing fields is maximised through effective management.

Comhairle Chontae Atha Cliath Theas

Record of Executive Business and Chief Executive's Order

Assessment

The main issues for consideration are:

- Zoning and Council policy,
- Visual Amenity,
- Parks & Landscaping,
- Environmental Health,
- Access & Parking,
- Procedural Issues,
- Services and Drainage,
- Site of Geological Interest
- Screening for Appropriate Assessment (AA),
- Screening for Appropriate Environmental Impact Assessment (EIAR).

Zoning and policy

The location of the proposed development is zoned 'OS', where the objective is '*To preserve and provide for open space and recreational facilities*'.

Within this zoning, '*Recreational Facility*' and '*Sports Club/Facility*' are '*Permitted in Principle*'.

Visual amenity

2 storey clubhouse (658sq.m)

The proposed two storey clubhouse will be located immediately south of the existing all weather pitch and to the north west of the community centre (Kilnamanagh AFC). The clubhouse will be built to the boundary with the community centre (Kilnamanagh AFC) where there are a significant number of mature trees. The clubhouse will have a flat parapet roof with a parapet height of c.7.0m. It will have a width of c.17.485m and a length of c.18.85m. The entrance door will be located in the north elevation and the southern elevation will have a blank façade. Fenestration treatment is considered to be broadly acceptable. The clubhouse will be located a distance of c.23.3m from the existing community centre. The clubhouse is considered visually acceptable.

External activity area with boundary fence (405sq.m)

The external activity area will be located immediately to the south east of the proposed two storey clubhouse. The external activity area will be built to the boundary with the community centre (Kilnamanagh AFC) to the south and will have a length of c.23.3m and a width 17.485m. The boundary fence will be c.3.8m high and will enclose the entire external activity area. From the drawings submitted the boundary fence appears to be of a weldmesh material however this is not fully clear. It is considered this can be addressed by way of **additional information**.

Parks & Landscaping,

The Parks Department has recommended **additional information** be requested. An extract taken from the Roads report states the following:

Comhairle Chontae Atha Cliath Theas

Record of Executive Business and Chief Executive's Order

*In relation to the above proposed development, this section has reviewed the application and recommends the following **additional information** below be requested from the applicant/developer*

1. Tree Survey

The applicant shall submit a detailed Tree Survey Report for the existing trees within the proposed development site. This shall comprise of a detailed Tree Survey, Arboricultural Impact Assessment and Tree Protection Plan all in accordance with, BS 5837: 2012 Trees in relation to design, demolition and construction – recommendations. The report shall be carried out by an independent, qualified Arborist.

2. Existing Trees and Hedgerows

There are concerns with the lack of information submitted in relation to existing trees and hedgerows within the site. The applicant is requested to submit a detailed tree and hedgerow survey report for the trees within the proposed development area. This tree survey should be undertaken by a suitably qualified arborist. The report should provide detailed information on the condition and health of the existing trees and it should also clearly detail what impacts the development will have on the trees and hedgerows but also potentially the tree roots.

It is considered appropriate to request the above **additional information**.

Environmental Health,

The Environmental Health Officer has recommended no objections subject to **conditions**. An extract taken from the EHO report states the following.

Development Summary:

*The above proposal is acceptable to the Environmental Health Department – subject to the following **conditions**:*

Construction Phases:

Noise

No Equipment or Machinery (to include pneumatic drills, construction vehicles, generators, etc.) shall be operated on or adjacent to the site before 7.00 hours on weekdays and 9.00 hours on Saturdays nor after 19.00 hours on weekdays and 13.00 hours on Saturdays, nor at any time on Sundays, Bank Holidays or Public Holidays. Any work outside these hours shall only be permitted following receipt of the written consent of the Planning Authority, having regard to the reasonable justification and No Equipment or Machinery (to include pneumatic drills, construction circumstances and a commitment to minimise as far as practicable any unwanted noise outside the hours stated above.

Reason: In the interest of public health by the prevention of unacceptable levels of noise pollution which could interfere with normal sleep and rest patterns and/or when people could reasonably expect a level of quietness.

Comhairle Chontae Atha Cliath Theas

Record of Executive Business and Chief Executive's Order

Plant equipment with low inherent potential for generation of noise shall be selected and used. Generators and high duty compressors shall be provided with localised barriers or acoustic barriers as appropriate.

Reason: In the interest of public health.

Air Quality

During the construction phase of the development, Best Practicable Means shall be employed to minimise air blown dust being emitted from the site. This shall include covering skips and slack-heaps, netting of scaffolding, daily washing down of pavements or other public areas, and any other precautions necessary to prevent dust nuisances.

Reason: To contain dust arising from construction / demolition in the interests of public health and to prevent nuisance being caused to occupiers of buildings in the vicinity.

It is considered appropriate to attach the above **conditions** in the event of a grant.

Access & Parking,

The Roads Department has recommended **additional information** be requested. An extract taken from the Roads report states the following.

Prior to commencement of any works in the public domain, and in order to comply with The Roads Act 1993 Section 13 Paragraph 10, a Road Opening Licence must be secured from South Dublin County Council, Roads Maintenance Department.

*Roads recommends that **additional information** be requested from the applicant:*

1. The applicant is requested to submit a revised layout showing the car parking, bicycle parking and pedestrian routes within the development. Please refer to Table 11.22: Minimum Bicycle Parking Rates– SDCC County Development Plan 2016-2022.

- a. The minimum width of footpaths shall be 1.8m wide to aid mobility impaired users.*
- b. All external bicycle parking spaces shall be covered.*
- c. Footpath layout shall provide adequate connectivity around the development and footpaths on the road.*

It is considered appropriate to request the above **additional information**.

Procedural Issues

It is noted that the applicant has not submitted a letter of consent for the proposed development. It is considered this may be addressed by way of **additional information**.

Services & Drainage

Reports received from both Irish Water and Surface Water Drainage recommend **Additional Information** be requested regarding requirements for Irish Water and Surface Water Drainage. An extract taken from the Irish Water report state the following:

*IW Recommendation: **Further Information** Required*

Comhairle Chontae Atha Cliath Theas

Record of Executive Business and Chief Executive's Order

1 Water (No Objection)

- Prior to the commencement of development, the applicant or developer shall enter into water connection agreement(s) with Irish Water.

Reason: In the interest of public health and to ensure adequate water facilities.

2 Foul (Further Information Required)

2.1 Submit a drawing in plan and cross-sectional view showing the distance between foundation of proposed clubhouse and existing 450mm foul sewer south east of site and the narrowest point. Submit a confirmation of feasibility letter from Irish Water agreeing to setback distance of proposed development to existing 450mm foul sewer south east of site.

- Prior to the commencement of development, the applicant or developer shall enter into waste water connection agreement(s) with Irish Water.

Reason: In the interest of public health and to ensure adequate waste water facilities.

It is considered appropriate to request the above **additional information**.

An extract taken from the Surface Water Drainage report state the following:

*Surface Water Report: **Further Information Required:***

1.1 Proposed development is close to an existing 675mm diameter surface water sewer south east of proposed clubhouse. Submit a drawing in plan and cross-sectional view showing the set-back distance between foundation of proposed development and adjacent 675mm surface water sewer south east of site. The distance between proposed development and existing 675mm surface water sewer shall be shown at the narrowest point between surface water sewer and proposed building.

1.2 There is no SuDS (Sustainable Drainage Systems) shown in proposed development. Submit a drawing showing what SuDS are proposed for the development. Example of SuDS include filter drains, channel rills, green roofs, tree pits, permeable paving, green area detention areas and other such SuDS. Show on drawing how surface water is being attenuated for proposed development before discharge to public surface water sewer.

Where SuDS is insufficient to attenuate surface water an additional arched type system can be used to attenuate surface water. The drawing shall also show the attenuation capacity of each attenuation type system proposed.

1.3 Submit a report to show surface water attenuation calculations for proposed development. The report shall show the site area in Hectares or m² and each of the different surface types in Hectares or m² such as building, roads pathways, permeable paving and grass areas and their respective run-off coefficients.

Flood Risk No Objection

The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.

Comhairle Chontae Atha Cliath Theas

Record of Executive Business and Chief Executive's Order

All new precast surface water manholes shall have a minimum thickness surround of 150mm Concrete Class B.

All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.

It is considered appropriate to request the above **additional information**.

Site of Geological Interest

The overall site overlaps with a Site of Geological Interest known as 'Greenhills Esker', which has a summary description within the County Development Plan, as follows, *'Large ridge comprising sand and gravel'*.

Section 9.7 of the Development Plan provides a policy and objective framework for Sites of Geological Interest. It is the policy of the Council to maintain the conservation value and seek the sustainable management of the County's geological heritage resource.

HCL19 Objective 1:

To protect designated County Geological Sites from inappropriate development and to promote the importance of such sites through the County's Heritage Plan.

The Geological Heritage of South Dublin County - An audit of County Geological Sites in South Dublin County informed the preparation of the Development Plan and provided an assessment of the features. Having regard to the existing levels of the site and the extent of development of playing pitches and the community centre in the area, it is considered that the proposal will have a minimal impact and would not constitute an inappropriate development.

Screening for Appropriate Assessment (AA)

The planning report submitted with the subject application states that, following preliminary assessment, the proposed development will not cause any direct impacts upon any Natura 2000 sites and that the risk of indirect impacts will be negligible. It is concluded that the proposed development will not cause any impacts on Natura 2000 sites and the Appropriate Assessment is not required.

Screening for Environmental Impact Assessment (EIAR)

Having regard to the modest nature of the proposed development, and the distance of the site from nearby sensitive receptors, there is no real likelihood of significant effects on the environment arising from the proposed development. The need for environmental impact assessment can, therefore, be excluded at preliminary examination and a screening determination is not required.

Comhairle Chontae Atha Cliath Theas

Record of Executive Business and Chief Executive's Order

Other Considerations

Development Contributions

- The proposal is for a two storey clubhouse (658sq.m) and an external activity area (405sq.m)
- From the information submitted there is no shop or bar being proposed as part of the above permission.
- Assessable area is Nil.

SEA Monitoring Information	
Building Use Type Proposed	Floor Area (sq.m.)
Recreational/ Sports Facility	1063sq.m.
Land Type	Site Area (Ha.)
Brownfield/Urban Consolidation	0.76933 ha.

Conclusion

Request additional information on the following items:

- Services & Drainage requirements.
- Roads Department requirements.
- Parks & Landscaping requirements.
- Letter of consent.
- Boundary fence.

Recommendation

Request Further Information.

Further Information

Further Information was requested on the 21st of April 2021.

Further Information was received on the 21st of October 2021 (not deemed significant).

Consultations

Water Services – no objections subject to conditions.

Irish Water – no objections subject to conditions.

Roads Department – request clarification of further information.

Public Realm Section – no objections subject to conditions.

Assessment

Item 1 Requested

The applicant is requested to submit the following information regarding Irish Water and Surface Water Drainage requirements:

(a) Proposed development is close to an existing 675mm diameter surface water sewer south east of proposed clubhouse. The applicant is requested to submit a drawing in plan and

Comhairle Chontae Atha Cliath Theas

Record of Executive Business and Chief Executive's Order

crosssectional view showing the set-back distance between foundation of proposed development and adjacent 675mm surface water sewer south east of site. The distance between proposed development and existing 675mm surface water sewer shall be shown at the narrowest point between surface water sewer and proposed building.

(b) There is no SuDS (Sustainable Drainage Systems) shown in proposed development. The applicant is requested to submit a drawing showing what SuDS are proposed for the development. Example of SuDS include filter drains, channel rills, green roofs, tree pits, permeable paving, green area detention areas and other such SuDS. Show on drawing how surface water is being attenuated for proposed development before discharge to public surface water sewer. Where SuDS is insufficient to attenuate surface water an additional arched type system can be used to attenuate surface water. The drawing should also show the attenuation capacity of each attenuation type system proposed.

(c) The applicant is requested to submit a report to show surface water attenuation calculations for proposed development. The report should show the site area in Hectares or m² and each of the different surface types in Hectares or m² such as building, roads pathways, permeable paving and grass areas and their respective run-off coefficients.

(d) The applicant is requested to submit a drawing in plan and cross-sectional view showing the distance between foundation of proposed clubhouse and existing 450mm foul sewer south east of site and the narrowest point. The applicant is requested to submit a confirmation of feasibility letter from Irish Water agreeing to setback distance of proposed development to existing 450mm foul sewer south east of site.

Assessment:

The applicant has submitted further information in response to this item including drawings showing the setback distances, SuDS and a report on the calculations. Water Services have reviewed the submitted further information and have no objections subject to conditions. This includes a condition to “*Include a Green Roof, Permeable Paving, tree pits and other such SuDS (Sustainable Drainage System) in proposed development*”.

In response to the request for the setback distance of the proposed development to the existing foul sewer the applicant has submitted a revised proposal that switches the location of the proposed building with the proposed external activity area. Irish Water have reviewed the further information and have no objections subject to conditions. This includes the condition that “*Prior to commencement of development submit a Confirmation Of Feasibility letter to the planning authority from Irish Water for proposed development. Agreement with Irish water with respect to setback distance boundary fence/flood light and adjacent existing 450mm foul sewer is required*”.

These reports are noted and should be conditioned as such in the event of a grant of permission.

Item 2 Requested

The applicant is requested to submit a revised layout showing the car parking, bicycle parking and pedestrian routes within the development. Please refer to Table 11.22: Minimum Bicycle Parking Rates– SDCC County Development Plan 2016-2022.

Comhairle Chontae Atha Cliath Theas

Record of Executive Business and Chief Executive's Order

- (a) The minimum width of footpaths shall be 1.8m wide to aid mobility impaired users.*
- (b) All external bicycle parking spaces shall be covered.*
- (c) Footpath layout shall provide adequate connectivity around the development and footpaths on the main road.*

Assessment:

The applicant has submitted a revised proposal that provides for an additional 16 bicycle parking spaces. It is noted that the proposed spaces do not appear to be located within the red line boundary. The submitted Site Access and Boundary Fence Treatment Drawing No. L(10)_PA provides a layout showing the car and bicycle parking layout and pedestrian routes within the site. The Roads Department have reviewed the proposed development and request a clarification of further information:

Drawing L10_(PA) has been submitted detailing pedestrian routes around the development and an additional 16 covered bicycle parking spaces. The vehicle parking has been identified within the neighbouring community centre and an access point to the proposed clubhouse has been identified.

Tables 11.23 and 11.24 of the county development plans set out the Maximum Parking rates for non-residential and residential development. Clubhouse and Gymnasium should have a maximum of 1 per 20sq.m GFA in zone 1. This equates to 33no. car parking spaces for this development, while this is a maximum allowable some amount of parking close to this figure should be available for the proposed development. The applicant is requested to identify the car parking spaces for this development on the drawing submitted.

Considering the drawing L10_(PA) roads require the submission of further information.

Clarification of information.

- 1. The quantity of car parking spaces shall be identified on a revised layout of not less than 1:200 for use by the proposed development in accordance with the current county development plan and the existing community centres quantity of car parking be identified on the same drawing.*
- 2. A revised layout of not less than 1:200 showing the car parking, showing a swept path analysis drawing (i.e. Autotrack or similar) demonstrating that vehicles can access the parking, ensuring there is a minimum of 6.0m space behind perpendicular parking spaces.*
- 3. The applicant shall provide 5% of vehicular parking spaces for mobility impaired users, and 10% vehicular parking spaces to be equipped with electrical charging points, REASON: In the interest of sustainable transport.*
- 4. Revised layout of not less than 1:100 scale, showing a swept path analysis drawing (i.e. Autotrack or similar) demonstrating that fire tenders/emergency vehicles can access/egress the site through the "emergency access" point.*
- 5. A revised layout of not less than 1:200 showing a suitable set down area to accommodate the car drop-off and pick-ups from the development.*
- 6. A mobility plan showing the mode of travel used by people arriving and leaving the development. (Car, walking and public transport). The number and time periods for car drop-offs and pick-ups of match fixtures etc.*

Comhairle Chontae Atha Cliath Theas

Record of Executive Business and Chief Executive's Order

7. *Revised layout of not less than 1:100 scale, showing a swept path analysis drawing (i.e. Autotrack or similar) demonstrating that refuse vehicles can access/egress the site through the vehicular access point.*

The car parking layout submitted shows that an existing total of 71 car parking spaces are provided for the overall development, including 5 for mobility impaired users. The proposed development would involve an increase in the floor area of the development and no changes to the car parking provision is proposed. The concerns of the Roads Department in relation to car parking are noted, however, the Planning Department considers that there is adequate car parking existing.

Item 3 Requested

The applicant is requested to submit the following information:

(a) Tree Survey : The applicant is requested to submit a detailed Tree Survey Report for the existing trees within the proposed development site. This should comprise of a detailed Tree Survey, Arboricultural Impact Assessment and Tree Protection Plan all in accordance with, BS 5837: 2012 Trees in relation to design, demolition and construction – recommendations. The report should be carried out by an independent, qualified Arborist. This request for additional information is being made to ensure the protection, safety, prudent retention and long-term viability of trees to be retained on and immediately adjacent to the site.

(b) Existing Trees and Hedgerows: There are concerns with the lack of information submitted in relation to existing trees and hedgerows within the site. The applicant is requested to submit a detailed tree and hedgerow survey report for the trees within the proposed development area. This tree survey should be undertaken by a suitably qualified arborist. The report should provide detailed information on the condition and health of the existing trees and it should also clearly detail what impacts the development will have on the trees and hedgerows but also potentially the tree roots.

Assessment: The applicant has submitted an Arboricultural Report, Tree Assessment Plan, and Tree Protection Plan. These identify that seven trees would be removed to facilitate the proposed development. It is recommended that seven new trees are planted approx. 2-3 m away from the existing security fence and masonry wall. The Public Realm Section have reviewed the further information and have no objections subject to conditions in relation to compensatory planting, tree works and a tree bond. This report is noted and should be conditioned as such.

Item 4 Requested

The applicant is requested to submit a letter of consent for the proposed development from the land owner.

Assessment: The applicant has submitted a letter of consent of the land owner, South Dublin County Council. This item has been satisfactorily addressed.

Comhairle Chontae Atha Cliath Theas

Record of Executive Business and Chief Executive's Order

Item 5 Requested

The applicant is requested to submit clear drawings to confirm the type of boundary fence proposed. It should be noted that palisade fencing is not acceptable to the Planning Authority.

Assessment: The applicant has submitted Drawing No. L(10)_PA that shows that PPC aluminium frame with PE-coated grid mesh fence to match the existing fence around the adjacent Astro pitch. This is considered to be visually acceptable.

Overall assessment: In response to addressing the further information items the applicant has submitted a revised site layout where the proposed building and external activity area has switched locations. This has resulted in internal and external amendments to the proposed building. Given the location, scale and design of the proposed building it is acceptable in terms of visual and residential amenity.

The extent of the proposed development would remain largely the same as originally assessed, save for additional bicycle parking spaces, and so it is still considered that it would have a minimal impact in terms of geological impact.

Given the above it is considered that the further information items have been addressed and the application can be granted.

Other Considerations

Development Contributions

- The proposal is for a two storey clubhouse (658sq.m) and an external activity area (405sq.m)
- From the information submitted there is no shop or bar being proposed as part of the above permission.
- Assessable area is Nil.

SEA Monitoring Information	
Building Use Type Proposed	Floor Area (sq.m.)
Recreational/ Sports Facility	1063sq.m.
Land Type	Site Area (Ha.)
Brownfield/Urban Consolidation	0.734 ha.

Conclusion

Having regard to the:

- provisions of the South Dublin County Development Plan 2016-2022,
- the established character of the area, and
- the nature and scale of the proposed development,

it is considered that, subject to the conditions set out below, the proposed development would be in compliance with Council policy, would not seriously injure the amenities of the area or of

Comhairle Chontae Atha Cliath Theas

Record of Executive Business and Chief Executive's Order

property in the vicinity and would, therefore, be in accordance with the proper planning and sustainable development of the area.

Recommendation

I recommend that a decision be made pursuant to the Planning & Development Act 2000, as amended, for the reasons set out in the First Schedule hereto, to Grant Permission for the said development in accordance with the said plans and particulars, subject to the condition(s) specified in the Second Schedule hereto, the reasons for the imposition of the said condition(s) being as set out in the said Second Schedule.

FIRST SCHEDULE

It is considered that the proposed development accords with the policies and objectives of South Dublin County Council, as set out in the South Dublin County Council Development Plan 2016 - 2022 and subject to the conditions set out hereunder in the Second Schedule is hereby in accordance with the proper planning and sustainable development of the area.

SECOND SCHEDULE

Conditions and Reasons

1. Development to be in accordance with submitted plans and details.
The development shall be carried out and completed in its entirety in accordance with the plans, particulars and specifications lodged with the application, and as amended by Further Information received on the 21st of October 2021, save as may be required by the other conditions attached hereto.
REASON: To ensure that the development shall be in accordance with the permission, and that effective control be maintained.
2. Irish Water Connection Agreement.
Prior to the commencement of development the applicant or developer shall enter into water and/or wastewater connection agreement(s) with Irish Water.
REASON: In the interest of public health and to ensure adequate water/wastewater facilities.
3. Foul Sewer.
Prior to commencement of development the applicant shall submit to the Planning Authority a Confirmation Of Feasibility letter from Irish Water for the proposed development and this shall include an agreement with Irish Water with respect to setback distance of boundary fence/flood light and adjacent existing 450mm foul sewer.
REASON: In the interest of public health and to ensure adequate waste water facilities.
4. Surface Water.
The disposal of surface water shall fully comply with all of the technical requirements of the Council's Water Services Section. In this regard, prior to the commencement of

Comhairle Chontae Atha Cliath Theas

Record of Executive Business and Chief Executive's Order

development, the applicant/developer shall submit for the written agreement of the Planning Authority information including Permeable Paving, tree pits and other such SuDS (Sustainable Drainage System).

REASON: In the interests of public health, safety, the proper planning and sustainable development of the area and in order to ensure adequate and appropriate surface water drainage provision.

5. Roads.

(a) Within 6 months of operation, a Mobility Management Plan shall be submitted to the Planning Authority for written agreement showing the mode of travel used by people arriving and leaving the development (car, walking and public transport, the number and time periods for car drop-offs and pick-ups of match fixtures etc.).

(b) Prior to commencement of development, a revised layout of not less than 1:100 scale, showing a swept path analysis drawing (i.e. Autotrack or similar) demonstrating that refuse vehicles can access/egress the site through the vehicular access point.

REASON: in the interest of traffic and pedestrian safety.

6. Landscaping.

The applicant shall provide compensatory planting to replace those trees being removed (7 in total) in order to accommodate the proposed development. The specific time of planting, location, nature and species types of the compensatory planting shall be agreed in writing with the Public Realm Section prior to the commencement of development.

REASON: In the interests of the amenity and environmental quality of the locality and to assimilate the development into its surroundings, in accordance with policy G2 Objective 9, G4 Objective 5, G2 Objective 13, G6 Objective 1, HCL15 Objective 3 of the CDP 2016-2022

7. Tree Works

All works shall be carried out in accordance with BS5837:2012 Trees in relation to design, demolition and construction. If, during construction, it becomes apparent that further works or changes are required, work shall not progress any further on site until the applicant has secured a site meeting with a suitably qualified professional to agree the details and phasing of any tree surgery works not detailed in the submitted report. A written schedule shall be submitted to and approved in writing by Public Realm Section.

REASON: To ensure that the trees on site are adequately protected, to safeguard the character and appearance of the area, in accordance with policy G2 Objective 9, G4 Objective 5, G2 Objective 13, G6 Objective 1, HCL15 Objective 3 of the CDP 2016-2022.

8. Tree Bond

A maximum of two weeks from the date of Commencement Notice within the meaning of Part II of the Building Control Regulations 1997 and prior to the commencement of any works on site, a Bond or bank draft to the value of €5,000 shall be lodged with the Planning Authority as a security for the protection and retention of the existing trees to be retained within the subject site during the course of the development works. The release of the bond will be considered a minimum 12 months after the completion of all site works,

Comhairle Chontae Atha Cliath Theas

Record of Executive Business and Chief Executive's Order

at the discretion of the Landscape/Public Realm Section. This will involve assessment of whether the trees specified for retention have been preserved in their prior condition and have suffered no damage and the developer has complied with the requirements of the Planning Authority in relation to tree protection.

REASON: In the interest of the proper planning and sustainable development of the area, street-tree protection, and the maintenance of the county's green infrastructure.

9. Noise.

(a) Noise levels from the proposed development shall not be so loud, so continuous, so repeated, of such duration or pitch or occurring at such times as to give reasonable cause for annoyance to a person in any residence, adjoining premises or public place in the vicinity.

(b) Noise due to the normal operation of the proposed development, expressed as LAeq over 15 minutes at the façade of a noise sensitive location, shall not exceed the daytime background level i.e. 0700 – 1900 by more than 10 dB(A) and shall not exceed the background level for evening and night time i.e. 1900 - 0700. Clearly audible and impulsive tones at noise sensitive locations during evening and night shall be avoided irrespective of the noise level.

(c) All mechanical plant and ventilation inlets and outlets should be sound insulated and/or fitted with sound attenuators as necessary to ensure that the noise level as expressed as LAeq over 15 minutes at 1 meter from the façade of any noise sensitive location does not exceed the background level by more than 10 dB(A) for daytime and shall not exceed the background level for evening and night time.

REASON: In the interests of public health and the proper planning and sustainable development of the area.

10. Minimise Air Blown Dust.

During the construction and or demolition phase of the development, Best Practicable Means shall be employed to minimise air blown dust being emitted from the site. This shall include covering skips and slack-heaps, netting of scaffolding, daily washing down of pavements or other public areas, and any other precautions necessary to prevent dust nuisances. The applicant/developer shall comply with British Standard B.S. 5228 Noise Control on Construction and Open sites and British Standard B.S. 6187 Code of Practice for demolition.

REASON: In the interest of public health and to uphold the Council's policies set out in the South Dublin County Council Development Plan.

11. Construction Noise and Hours.

To control, limit and prevent the generation of unacceptable levels of Environmental Noise Pollution from occurring during construction activity, no Equipment or Machinery (to include pneumatic drills, on-site construction vehicles, generators, etc.) that could give rise to unacceptable levels of noise pollution as set out generally for evening and night-time in S.I. No. 140/2006 - Environmental Noise Regulations 2006 shall be operated on the site before 7.00 hours on weekdays and 9.00 hours on Saturdays nor after 19.00 hours on weekdays and 13.00 hours on Saturdays, nor at any time on Sundays, Bank Holidays or

Comhairle Chontae Atha Cliath Theas

Record of Executive Business and Chief Executive's Order

Public Holidays.

Any construction work outside these hours that could give rise to unacceptable levels of noise pollution shall only be permitted following a written request to the Planning Authority and the subsequent receipt of the written consent of the Planning Authority, having regard to the reasonable justification and circumstances and a commitment to minimise as far as practicable any unacceptable noise outside the hours stated above. In this respect, the applicant or developer shall also comply with BS 5228:2009 Noise and Vibration Control on Construction and Open Sites, and have regard to the World Health Organisation (WHO) – Guidelines for Community Noise (1999).

The applicant or developer shall also endeavour to engage in local consultation in respect of any noise sensitive location within 30 metres of the development as approved prior to construction activity commencing on site. Such noise sensitive locations should be provided with the following:

- Schedule of works to include approximate timeframes
- Name and contact details of contractor responsible for managing noise complaints
- Hours of operation- including any scheduled times for the use of equipment likely to be the source of significant noise.

REASON: In the interest of public health by the prevention of unacceptable levels of noise pollution which could interfere with normal sleep and rest patterns and/or when people could reasonably expect a level of quietness, the proper planning and sustainable development of the area and to uphold the Council's amenity policies set out in the South Dublin County Council Development Plan.

NOTE: The applicant is advised that under the provisions of Section 34 (13) of the Planning and Development Act 2000 (as amended) a person shall not be entitled solely by reason of a permission to carry out any development.


NOTE: The applicant or developer should ensure that all necessary measures shall be taken by the contractor to prevent the spillage or deposit of clay, rubble or other debris on adjoining roads during the course of the works and to ensure that any such instances arising are remedied immediately.

Comhairle Chontae Atha Cliath Theas

Record of Executive Business and Chief Executive's Order

REG. REF. SD21A/0044


LOCATION: Treepark Road, Kilnamanagh, Dublin 24



Jim Johnston,
Senior Executive Planner

ORDER: A decision pursuant to Section 34(1) of the Planning & Development Act 2000, as amended, to Grant Permission for the reasons set out in the First Schedule above, in accordance with the said plans and particulars, subject to the condition(s) specified in the Second Schedule above, the reasons for the imposition of the said condition(s) being as set out in the said Second Schedule is hereby made.

Date: 18/11/21



Eoin Burke, Senior Planner