

Bos na Poist 174,  
46/49 Stráid Uí Chonaill Uacht,  
Baile Átha Cliath 1.  
Guthán (01) 727777  
Fax. 725782



P.O. Box 174,  
46/49 Upper O'Connell Street,  
Dublin 1.  
Telephone (01) 727777  
Fax. 725782

SEAN WALSH, M.C.C.,  
CHAIRMAN, DUBLIN COUNTY COUNCIL.

## DUBLIN COUNTY COUNCIL

Personal Callers/  
Enquiries to:  
Liffey House  
24/28 Tara Street  
Dublin 2  
Telephone 773066

BUILDING BYE LAWS

APPROVAL NOTICE

Address for  
Correspondence:  
Building Control Section  
Planning Dept.  
Block 2  
Irish Life Centre  
Lower Abbey Street  
Dublin 1

Application received: 14/8/1989  
Applicant: Sisters of Charity of St. Paul the Apostle.  
Submitted by: Murray O'Laoire Associates, 71 Lr. Baggot St., Dublin 2.  
Reg. No.: 89A/1498  
Order No.: BBL/3317/89  
Proposal: Reinstatement of fire damaged assembly and community hall.  
Location: St. Paul's Secondary School, Greenhills, Walkinstown.

Notice is hereby given that the Council has approved the plans submitted by you for the work described above subject to the following conditions:

- (1) That the applicant submits the statutory notice of commencement and completion of work in accordance with Bye Law no's 114 and 117. Premises should not be occupied until the requirements of these Bye Laws have been fulfilled.
- (2) The applicant must comply with the requirements of the Chief Fire Officer where applicable.

*Note A* The Chief Fire Officer's requirements include the provisions of Parts, N, P, Q and R of the Proposed Building Regulations issued by the Department of the Environment.

*Note B* The Applicant is advised to comply with the provisions of the Proposed Building Regulations issued by the Department of the Environment.

- (3) That all work be in accordance with Dublin County Council Building Bye Laws.
- (4) That full details of the structural members be submitted accompanied by full design calculations.
- (5) That the foul and surface water drainage systems be completed to the satisfaction of the Building Control Department.
- (6) That an adequate water supply system be provided for fire fighting purposes.

**NOTE:** Applicant to consult and agree with Sanitary Services Water Section in relation to increasing the water pressure in the existing fire main for fire fighting purposes.


- (3) That all work be in accordance with Dublin County Council Building Bye Laws.
- (4) That full details of the structural members be submitted accompanied by full design calculations.
- (5) That the foul and surface water drainage systems be completed to the satisfaction of the Building Control Department.
- (6) That an adequate water supply system be provided for fire fighting purposes.

**NOTE:** Applicant to consult and agree with Sanitary Services Water Section in relation to increasing the water pressure in the existing fire main for fire fighting purposes.

- Important**
- (1) It is illegal to proceed with the approved work until permission or exemption under the Local Government (Planning & Development) Acts has been obtained.
  - (2) At least two clear days notice in writing must be given to the Building Control Section,
    - (a) of the date on which execution of the work will be commenced.
    - (b) before proceeding with the covering up of any drain or the filling in any foundation.
  - (3) Any liability or consequential loss arising from the omission or misrepresentation of existing services, which affect the site, on the lodged plans is the responsibility of the applicant.

Date:

**- 5 OCT 1989**

  
J. CARSON  
Senior Administrative Officer

**N.B.** Inspection forms are attached for completion and return to Senior Engineer, Dublin County Council, Building Control Section, Block 2, Irish Life Centre, Lr. Abbey Street, Dublin 1, when the work reaches the stage set out in the relevant forms, not less than 2 clear days before the inspection is to be made. Where appropriate, Architects should pass inspection forms to Builders.

FUTURE PRINT LTD.