



LEGEND


- REFER TO ARCHITECTS DRAWINGS FOR SITE BOUNDARY LINE
- OUTLINE OF WAYLEAVE FOR EXISTING 4000 WATERMAIN
- PROPOSED SURFACE WATER SEWER
- PROPOSED FILTER DRAIN

NOTES:

1. THIS DRAWING SHALL BE READ IN CONJUNCTION WITH ALL OTHER DRAWINGS
2. ALL LEVELS ARE IN METRES O.D. MALIN HEAD.
3. THE POSITION AND LEVELS OF EXISTING SERVICES INsofar AS THEY ARE KNOWN AND AS SHOWN ON THE DRAWINGS MAY NOT BE ACCURATE AND MERELY INDICATE THEIR PRESENCE IN THE WORKING AREA. THE CONTRACTOR IS RESPONSIBLE FOR LOCATING EXISTING SERVICES ON SITE.
4. THE SURVEY INFORMATION SHOWN ON THIS DRAWING IS TAKEN FROM A TOPOGRAPHICAL SURVEY UNDERTAKEN BY MURPHY GEOSPATIAL IN MAY 2021, DRAWING REFERENCE MGL41890_T_ITM_Rev2.
5. FOR DETAILS OF LONGITUDINAL SECTIONS REFER TO DRG. No. 21003-TJOC-ZZ-ZZ-DR-C-008, 21003-TJOC-ZZ-ZZ-DR-C-009 & 21003-TJOC-ZZ-ZZ-DR-C-070.
6. FOR DETAILS OF MANHOLES REFER TO DRG. No. 21003-TJOC-ZZ-ZZ-DR-C-076 & 21003-TJOC-ZZ-ZZ-DR-C-077.
7. FOR DETAILS OF BEDDING REFER TO DRG. No. 21003-TJOC-ZZ-ZZ-DR-C-074.
8. FOR DETAILS OF BUILDING DRAINAGE CONNECTIONS REFER TO ARCHITECTS AND M/E DRAWINGS
9. ALL PIPEWORK IS 150mmØ UNLESS OTHERWISE NOTED.
10. WHERE EXCAVATIONS FOR DRAINAGE ENCRUSH ON THE BEARING FOR FOUNDATIONS (I.E. PIPE IS BELOW FOUNDATION OR BELOW 45° LINE EXTENDING OUT AND DOWN FROM THE BOTTOM OF THE FOUNDATION), SUCH EXCAVATIONS SHALL BE BACKFILLED IN LEAN MIX CONCRETE TO FORMATION LEVEL OF FOUNDATIONS. NEW FOUNDATIONS WILL BE INSTALLED AT A DEPTH TO SUIT THE PROPOSED NEW DRAINAGE.
11. PIPE BEDDING AND BACKFILL SHALL BE AS PER DRAWING 21003-TJOC-ZZ-ZZ-DR-C-074 WITH CLASS B BEDDING FOR FLEXIBLE PIPE (PVC AND THERMOPLASTIC STRUCTURED WALL PIPE) AND CLASS B BEDDING FOR RIGID PIPE (CONCRETE). BACKFILLING OF TRENCHES ABOVE PIPE BED AND SURROUND SHALL BE CLASS B04 MATERIAL WHERE TRENCHES ARE BENEATH ROADS, UNLESS SITUATION AS PER NOTE TO ABOVE. WHERE PIPES ARE LAID UNDER SLABS AND CONCRETE SURFACES, THE TRENCHES SHALL BE BACKFILLED WITH HARDCORE COMPLYING WITH THE REQUIREMENTS OF S21 AND IS EN 13242.
12. SURFACE WATER SEWERS WITH A DIAMETER OF 150mm AND 225mm SHALL BE PVC. ALL SURFACE WATER SEWERS WITH A DIAMETER OF 300mm AND GREATER SHALL BE CONCRETE PIPES UNLESS NOTED OTHERWISE. REFER TO LONG SECTIONS FOR SPECIFIED PIPE MATERIAL.
13. WHERE AN UNDERGROUND PIPE IS BUILT INTO A STRUCTURE THERE SHALL BE TWO FLEXIBLE JOINTS ADJACENT TO THE STRUCTURE. THE FIRST SHALL BE NOT MORE THAN ONE PIPE DIAMETER FROM THE OUTSIDE FACE OF THE STRUCTURE. THE LENGTH OF THE NEXT PIPE (ROCKER PIPE) SHALL NOT EXCEED 750mm FOR PIPES UP TO 4500.
14. SETTING OUT OF ALL SVPs AND RWPs TO ARCHITECTS DETAILS.
15. DRAINAGE TO LANDSCAPED AND NON CARRIAGEWAY PAVED AREAS BY LANDSCAPE ARCHITECTS.
16. ALL MANHOLES TO BE SET OUT ON SITE AND CO-ORDINATED WITH PROPOSED AND EXISTING SERVICES PRIOR TO CONSTRUCTION.
17. COVER LEVEL TO BE CO-ORDINATED WITH PROPOSED LANDSCAPING LEVELS.
18. ALL MANHOLE COVERS IN TRAFFICATED AREAS TO BE A MINIMUM OF CLASS D400 SOLID TOP COVERS. RECESSED COVERS TO BE PROVIDED IN PAVED LANDSCAPED AREAS.

PROPOSED ATTENUATION STORAGE:
 STORMTECH STORAGE SYSTEM PROVIDING
 136.0m³ STORAGE IN 48 No. SC740 CHAMBERS
 (PLAN AREA @ BASE = 166.0m²)
 STORMTECH SYSTEM LEVELS:
 92.030m BASE OF EXCAVATION
 92.330m TOP OF STONE BASE
 (92.347 T.W. 100 YR EVENT)
 93.090m TOP OF STORMTECH UNITS
 93.240m TOP OF STONE
 93.850m GROUND LEVEL COVER.
 REFER TO DRG. 21003-TJOC-ZZ-ZZ-DR-C-0071
 FOR FURTHER DETAILS.

NOTE: WHERE FOUL SEWERS OR SURFACE WATER PIPES CROSS OVER THE EXISTING WATERMAIN, THEY SHALL CROSS AT RIGHT ANGLES TO THE EXISTING WATERMAIN AND SHALL BE LOCATED MIDWAY BETWEEN THE WATERMAIN JOINTS. THERE SHALL BE A MINIMUM OF 500mm VERTICAL SEPARATION DISTANCE BETWEEN THE TOP OF EXISTING WATERMAIN AND UNDERSIDE OF FOUL SURFACE WATER PIPE AT THE CROSSING POINT



C01	AP	ISSUED FOR PLANNING	18.11.2021
REV	STAT	DESCRIPTION	DATE

DRAWING STATUS:		
ISSUED FOR PLANNING		
CHECKED BY:	REVIEWED BY:	APPROVED BY:
RON	JM	JM

NO PART OF THIS DOCUMENT MAY BE REPRODUCED OR TRANSMITTED IN ANY FORM OR STORED IN ANY RETRIEVAL SYSTEM OR ANY MANNER WITHOUT THE WRITTEN PERMISSION OF THE CONSULTING ENGINEER AS COPYRIGHT HOLDER EXCEPT AS AGREED FOR USE ON THE PROJECT FOR WHICH THE DOCUMENT WAS ORIGINALLY ISSUED.

TJ O'CONNOR & ASSOCIATES
 CONSULTING ENGINEERS
 CORRIG HOUSE, CORRIG ROAD, SANDYFORD, DUBLIN 18.
 Tel: 01-295 2321 Fax: 01-295 4541 Email: tjoc@tjoc.ie Web: www.tjoc.ie

PROJECT:	PROPOSED RESIDENTIAL DEVELOPMENT AT GORDON PARK
CLIENT:	GREENWALK DEVELOPMENT LTD.
DRAWING TITLE:	PROPOSED SURFACE WATER LAYOUT SHEET 1
SCALE:	1:250 (A1)
PROJECT - ORIGINATOR - VOLUME - LOCATION - TYPE - ISSUE NUMBER:	21003-TJOC-ZZ-ZZ-DR-C-0065
REV:	C01