



LEGEND

- REFER TO ARCHITECTS DRAWINGS FOR SITE BOUNDARY LINE
- OUTLINE OF WAYLEAVE FOR EXISTING 4000 WATERMAIN
- PROPOSED SURFACE WATER SEWER
- PROPOSED FILTER DRAIN

NOTES:

1. THIS DRAWING SHALL BE READ IN CONJUNCTION WITH ALL OTHER DRAWINGS.
2. ALL LEVELS ARE IN METRES O.D. MAIN HEAD.
3. THE POSITION AND LEVELS OF EXISTING SERVICES INsofar AS THEY ARE KNOWN AND AS SHOWN ON THE DRAWINGS MAY NOT BE ACCURATE AND MERELY INDICATE THEIR PRESENCE IN THE WORKING AREA. THE CONTRACTOR IS RESPONSIBLE FOR LOCATING EXISTING SERVICES ON SITE.
4. THE SURVEY INFORMATION SHOWN ON THIS DRAWING IS TAKEN FROM A TOPOGRAPHICAL SURVEY UNDERTAKEN BY MURPHY GEOSPATIAL IN MAY 2021, DRAWING REFERENCE MGL41890_T_ITM_Rev2.
5. FOR DETAILS OF LONGITUDINAL SECTIONS REFER TO DRG. No. 21003-TJOC-ZZ-ZZ-DR-C-0068, 21003-TJOC-ZZ-ZZ-DR-C-0069 & 21003-TJOC-ZZ-ZZ-DR-C-0070.
6. FOR DETAILS OF MANHOLES REFER TO DRG. No. 21003-TJOC-ZZ-ZZ-DR-C-0076 & 21003-TJOC-ZZ-ZZ-DR-C-0077.
7. FOR DETAILS OF BEDDING REFER TO DRG. No. 21003-TJOC-ZZ-ZZ-DR-C-0074.
8. FOR DETAILS OF BUILDING DRAINAGE CONNECTIONS REFER TO ARCHITECTS DRAWINGS AND I-ME DRAWINGS.
9. ALL PIPEWORK IS 150mmØ UNLESS OTHERWISE NOTED.
10. WHERE EXCAVATIONS FOR DRAINAGE ENCROACH ON THE BEARING FOR FOUNDATIONS (I.E. PIPE IS BELOW FOUNDATION OR BELOW 45° LINE EXTENDING OUT AND DOWN FROM THE BOTTOM OF THE FOUNDATION), SUCH EXCAVATIONS SHALL BE BACKFILLED IN LEAN MIX CONCRETE TO FORMATION LEVEL OF FOUNDATIONS. NEW FOUNDATIONS WILL BE INSTALLED AT A DEPTH TO SUIT THE PROPOSED NEW DRAINAGE.
11. PIPE BEDDING AND BACKFILL SHALL BE AS PER DRAWING 21003-TJOC-ZZ-ZZ-DR-C-0074 WITH CLASS E BEDDING FOR FLEXIBLE PIPE (UPVC AND THERMOPLASTIC STRUCTURED WALL PIPE) AND CLASS B BEDDING FOR RIGID PIPE (CONCRETE). BACKFILLING OF TRENCHES ABOVE PIPE BED AND SURROUND SHALL BE CLASS B04 MATERIAL WHERE TRENCHES ARE BENEATH ROADS. UNLESS SITUATION IS AS PER NOTE 10 ABOVE, WHERE PIPES ARE LAID UNDER SLABS AND CONCRETE SURFACES, THE TRENCHES SHALL BE BACKFILLED WITH HARD CORE COMPLYING WITH THE REQUIREMENTS OF SR21 AND IS EN 13242.
12. SURFACE WATER SEWERS WITH A DIAMETER OF 150mm AND 225mm SHALL BE UPVC. ALL SURFACE WATER SEWERS WITH A DIAMETER OF 300mm AND GREATER SHALL BE CONCRETE PIPES UNLESS NOTED OTHERWISE. REFER TO LONG SECTIONS FOR SPECIFIED PIPE MATERIAL.
13. WHERE AN UNDERGROUND PIPE IS BUILT INTO A STRUCTURE THERE SHALL BE TWO FLEXIBLE JOINTS ADJACENT TO THE STRUCTURE. THE FIRST SHALL BE NOT MORE THAN ONE PIPE DIAMETER FROM THE OUTSIDE FACE OF THE STRUCTURE. THE LENGTH OF THE NEXT PIPE (ROCKER PIPE) SHALL NOT EXCEED 750mm FOR PIPES UP TO 4500.
14. SETTING OUT OF ALL SVI'S AND RWP'S TO ARCHITECTS DETAILS.
15. DRAINAGE TO LANDSCAPED AND NON CARRIAGEWAY PAVED AREAS BY LANDSCAPE ARCHITECTS.
16. ALL MANHOLES TO BE SET OUT ON SITE AND CO-ORDINATED WITH PROPOSED AND EXISTING SERVICES PRIOR TO CONSTRUCTION.
17. COVER LEVEL TO BE CO-ORDINATED WITH PROPOSED LANDSCAPING LEVELS.
18. ALL MANHOLE COVERS IN TRAFFICKED AREAS TO BE A MINIMUM OF CLASS D400 SOLID TOP COVERS. RECESSED COVERS TO BE PROVIDED IN PAVED LANDSCAPED AREAS.

C01	AP	ISSUED FOR PLANNING	18.11.2021
-----	----	---------------------	------------

REV	STAT	DESCRIPTION	DATE
DRAWING STATUS:			
ISSUED FOR PLANNING			

CHECKED BY: RON	REVIEWED BY: JM	APPROVED BY: JM
--------------------	--------------------	--------------------

NO PART OF THIS DOCUMENT MAY BE REPRODUCED OR TRANSMITTED IN ANY FORM OR STORED IN ANY RETRIEVAL SYSTEM OF ANY NATURE WITHOUT THE WRITTEN PERMISSION OF THE CONSULTING ENGINEER AS COPYRIGHT HOLDER EXCEPT AS AGREED FOR/IN WRITING ON THE PROJECT FOR WHICH THE DOCUMENT WAS ORIGINALLY ISSUED.

TJ O'CONNOR & ASSOCIATES
CONSULTING ENGINEERS

CORRIG FINE, CORRIG ROAD, SANDYFORD, DUBLIN 18.
Tel: 01-295 2321 Fax: 01-295 4541 Email: tjoc@tjoc.ie Web: www.tjoc.ie

PROJECT:	PROPOSED RESIDENTIAL DEVELOPMENT AT GORDON PARK
CLIENT:	GREENWALK DEVELOPMENT LTD.
DRAWING TITLE:	PROPOSED SURFACE WATER LAYOUT SHEET 2

SCALE:	1:250	(A1)
PROJECT ORIGINATOR - VOLUME - LOCATION - TYPE - REVISION NUMBER	21003-TJOC-ZZ-ZZ-DR-C-0066	REV: C01