



WATERMAIN LEGEND

- EXISTING WATERMAIN
- PROPOSED 100mm Ø (ID) HDPE WATERMAIN
- PROPOSED 150mm Ø (ID) HDPE WATERMAIN
- PROPOSED 200mm Ø (ID) HDPE WATERMAIN
- SV SLUICE VALVE
- SCV SCOUR VALVE
- H HYDRANT
- WH WASHOUT HYDRANT
- AV AIR VALVE
- M WATER METER
- BB BOUNDARY BOX WITH 1/2" CONNECTION

All external manifold chambers constructed as per Section 3.14 of the Water Code of Practice. All meters in the manhole shall be tagged to indicate which property is supplied and any unused outputs are to be blanked off.

Rev.	Date	Description	By
P2	09.12.2021	REDLINE BOUNDARY UPDATED	NMO
P1	15.11.2021	SITE LAYOUT UPDATED	CG

Project Title
**PHASE 3
 TUBBER LANE - ADAMSTOWN**

Architect
DAVEY & SMITH ARCHITECTS

Date: SEP 2021 By: CG Checked: PM Scale @ A1: 1:500

Drawing Title
**WATERMAIN LAYOUT
 SHEET 2 OF 3**

Drawing Status
PLANNING

Job No. 20065 Drawing No. 108 Issue P2

poga CONSULTING ENGINEERS
 Pat O'Gorman & Associates
 STRUCTURAL & CIVIL

Unit C2, Nutgrove Office Park
 Rathfarnham
 Dublin 14
 D14 CR20
 Tel +353 (0)1 205 1101
 www.poga.ie

Ordnance Survey Ireland Licence No. EI 0255338
 © Ordnance Survey Ireland / Government of Ireland
 © This drawing is Copyright and must only be used for the project named.
 S:\02-PROJECTS\2021\20065-Adamstown Phase 3\02-DRAWINGS\03-POGA Site Development\02-Planning\20065-100-110-R6.dwg, 15/12/2021 08:42:27