

Water Services Planning Report

Register Reference No.: SD21B/0286 AI
Development: Extension to side of existing house.
Location: 194, Arthur Griffith Park, Lucan, Co. Dublin
Application Type: Permission
Report Date: 22nd June 2021

Surface Water Report:

Clarification of Further information Required:

1.1 The applicant has proposed to discharge surface water run off from the proposed development to the foul water drainage network. The applicant is required to investigate the use of SuDS (Sustainable Drainage Systems) on site to infiltrate surface water to ground. Failing this, the applicant is required to investigate connection of stormwater run off to the public storm water system in the area. The applicant shall contact South Dublin County Council's Water and Drainage Section to discuss stormwater drainage proposals prior to response to this further information request.

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
-

Flood Risk Report:

No objection:

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Ronan Toft AE

Date: _____

Endorsed: _____
Brian Harkin SEE

Date: _____