

Water Services Planning Report

Register Reference No.: *SD21A/0255 AI*
Development: Construction of 2 three storey dwellings and associated ancillary site works.
Location: Hawthorns, Killakee Lawns, Firhouse, Dublin 24
Report Date : 26/01/2022

Surface Water Report:

No objection subject to:

Flood Risk

No objection

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
-

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Brian Harkin SEE.

Date: _____

Endorsed: _____
Chris Galvin SE.

Date: _____