

Water Services Planning Report

Register Reference No.: SD21A/0344
Development: 1 freestanding and illuminated entrance signage structure (c.5.46 metres in height and c.12.15 metres in length) displaying 'Liffey Valley' located adjacent to Fonthill Road and all associated ancillary site development works.
Location: Liffey Valley Shopping Centre, Fonthill Road, Clondalkin, Dublin 22
Report Date : 19th Jan 2022

Surface Water Report:

No Objection Subject to:

1.1 The applicant must ensure that minimum separation distances between the proposed signage structure and adjacent 900mm surface water sewer are as per the Greater Dublin Regional Code of Practice for Drainage Works are complied with.

Flood Risk

No Objection

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
-

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Padraig Slye GE.

Date: _____

Endorsed: _____
Brian Harkin SEE.

Date: _____