# EXTRACT OF LUMINAIRE SCHEDULE FOR SPECIFIED EXTERIOR LUMINAIRE




## Equipment Data Sheet Lighting Schedule

Job Title:DUB14/15Date:17/12/2021Job Number:279225-00Purpose of Issue: Issue for IFC02Revision:C03Stage:Issue for IFC02Made by:GKChecked by:SBLuminaire Reference: WP

#### **General Description**

Uniform and energy conscious illumination to walkways, parking lots, roadways, building areas and security lighting

Arm mounted



#### Luminaire

Manufacturer Catalogue number Finish

IP rating Luminaire Weight

	Eaton
	GLEON AF 06 LED E1 5WQ 7060
	TGIC polyester powder coat paint
IP66	
	With Arm 20 kg

#### Light Source

Type
Wattage
Colour / Beam
Luminous Flux
Colour Rendering
Service Life

Ballast

LED	
382 W	
5700K	
41 136 lm	
Ra>70	
60 000h	
-	

### **Control Gear / Transformer**

Туре	-
Dimmable	Yes
Location	Integral
Emergency power source	Central Battery

## **Fixture**

Location External

#### **Additional Information**

- 1. On-site warranty to include failure of all luminaire components, inclusive of driver, electronics and LED modules;
- 2. Contractor to include for all fixtures and fixings necessary for correct mounting and operation;
- 3. Contractor to ensure catalogue numbers are correct before ordering;
- 4. Colour of the finish and CCT to be confirmed with the architect prior to ordering;
- 5. Luminaires indicated as emergency with integral battery shall be equipped with 3 hour self contained, non-maintained conversic