

Water Services Planning Report

Register Reference No.: SD21A/0350

Development: Retention of constructed fence and boundaries and the relocation of existing access gate to revised location and proposed use of space as an allotment.

Location: Long Mile Road, Drimnagh, Dublin 12

Report Date : 2nd Feb 2022

Surface Water Report:

No Objection:

- 1 Within 5 weeks of planning decision submit a drawing showing the distance between foundation boundary of proposed fence and outside diameter of existing 225mm surface water sewer south of same. There shall be a minimum 3m setback distance from foundation of proposed fence to the outside diameter of existing 225mm surface water sewer south of same.

Flood Risk

No Objection

- All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
-

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Padraig Slye GE.

Date: _____

Endorsed: _____
Brian Harkin SEE.

Date: _____