

Water Services Planning Report

Register Reference No.: SD21A/0352

Development: Change of use from existing office accommodation (53.67sq.m) to new Sushi Take-Away shop consisting of new service counter with hatch to customer area at front, new internal kitchen, cold store, dry goods store & staff w.c., together with new shopfront signage to front elevation and all associated site works

Location: Unit 4a, St. John's House Retail Centre, Blessington Road, Tallaght, Dublin 24

Report Date : 2nd Feb 2022

Surface Water Report:

No Objection:

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
- All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works

Flood Risk

No Objection

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Padraig Slye GE.

Date: _____

Endorsed: _____
Brian Harkin SEE.

Date: _____