

Water Services Planning Report

Register Reference No.: SD21A/0357
Development: Single storey extension of 65sq.m to provide a new entrance and additional office space to the front of the existing club house; modifications to internal layout, demolition of existing entrance, together with new cladding & signage to the front of the building, alterations to existing parking spaces and all ancillary site works
Location: Newtown, Rathfarnham, Dublin 16
Report Date : 3rd Feb 2022

Surface Water Report:

No Objection:

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
- All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works

Flood Risk

No Objection

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Padraig Slye GE.

Date: _____

Endorsed: _____
Brian Harkin SEE.

Date: _____