

Water Services Planning Report

Register Reference No.: SD22A/0003

Development: A single storey, one bedroom log cabin in the rear garden.

Location: Rear Garden of, 61A, Dodsboro Cottages, Lucan, Co. Dublin.

Report Date : 09th Feb 2022

Surface Water Report:

No Objection Subject To:

1.1 Include where practical SuDS (Sustainable Drainage Systems) such as

- Permeable paving
- Grasscrete
- Planters boxes,
- Water butt/s
- other such SuDS.

Flood Risk

No Objection

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works
-

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Padraig Slye GE.

Date: _____

Endorsed: _____
Brian Harkin SEE.

Date: _____