

# Water Services Planning Report

**Register Reference No.:** SD21A/0229

**Development:** Retention for 2 bay portal frame, additional floor area to existing industrial unit. Permission for roofing of 2 bay portal frame structure; extension to existing industrial unit; construction of a concrete resurfaced area in main yard; minor internal layout and elevational revisions to existing industrial unit and all associated site works including underground surface water attenuation and related utilities and works.

**Location:** Heiton Steel, Ashfield, Naas Road, Clondalkin, Dublin

**Report Date :** 15<sup>th</sup> Feb 2022

---

## Surface Water Report:

**No Objection:**

### **Flood Risk**

### **No Objection**

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
  - All new precast surface water manholes shall have a minimum thickness surround of 150mm Concrete Class B.
  - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
- 

## Water Report:

**Referred to IW**

## Foul Drainage Report:

**Referred to IW**

Signed: \_\_\_\_\_  
Padraig Slye GE.

Date: \_\_\_\_\_

Endorsed: \_\_\_\_\_  
Brian Harkin SEE.

Date: \_\_\_\_\_