

Water Services Planning Report

Register Reference No.: SD21A/0229 AI

Development: Retention for 2 bay portal frame, additional floor area to existing industrial unit. Permission for roofing of 2 bay portal frame structure; extension to existing industrial unit; construction of a concrete resurfaced area in main yard; minor internal layout and elevational revisions to existing industrial unit and all associated site works including underground surface water attenuation and related utilities and works.

Location: Heiton Steel, Ashfield, Naas Road, Clondalkin, Dublin

Report Date : 15th Feb 2022

Surface Water Report:

No Objection:

Flood Risk

No Objection

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
 - All new precast surface water manholes shall have a minimum thickness surround of 150mm Concrete Class B.
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
-

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Padraig Slye GE.

Date: _____

Endorsed: _____
Brian Harkin SEE.

Date: _____