

Water Services Planning Report

Register Reference No.: SD22A/13

Development: The installation of an energy storage unit at an existing data centre facility. The development involves the placement of three ISO 40ft. shipping containers containing back up storage units at Keppel Data Centre, Citywest Avenue, Citywest Business Park, Dublin 24

Location: 4033, Citywest Avenue, Citywest Business Park, Dublin 24

Report Date : 14th Feb 2022

Surface Water Report:

No Objection:

Flood Risk

No Objection

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works
-

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Padraig Slye GE.

Date: _____

Endorsed: _____
Brian Harkin SEE.

Date: _____