

Water Services Planning Report

Register Reference No.: SD22A/0016
Development: Garden building to the rear of the property and the removal of existing piers, pedestrian gate and front wall replacing with a new driveway entrance consisting of new piers and wall forming a car parking area including a new crossover altered path verge with dished kerbs along with associated site works.
Location: 45 Muckcross Green, Perrystown Dublin 12
Report Date : 17th Feb 2022

Surface Water Report:

No Objection Subject To:

1.1 Prior to commencement of development submit a revised drawing showing plan and cross-sectional views, dimensions, and location of proposed soakaway. Any proposed soakaway shall be located fully within the curtilage of the property and shall be:

- At least 5m from any building, public sewer, road boundary or structure.
- Generally, not within 3m of the boundary of the adjoining property.
- Not in such a position that the ground below foundations is likely to be adversely affected.
- 10m from any sewage treatment percolation area and from any watercourse / floodplain.

1.2 The applicant shall include SuDS (Sustainable urban Drainage Systems) features for the proposed development such as but not limited to the following:

- Rain Gardens
- Planter boxes with overflow connection to the public surface water sewer.
- Permeable Paving
- Grasscrete
- Water butt/s

Flood Risk

No Objection

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works
-

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Water Services Planning Report

Signed: _____
Padraig Slye GE.

Date: _____

Endorsed: _____
Brian Harkin SEE.

Date: _____