

Water Services Planning Report

Register Reference No.: SD21A/0239 AI
Development: Alterations to an existing granted planning application (previously granted permissions Reg. Ref. SD18A/0314 [ABP-304148-19], SD19A/0408, SD20A/0187); reconfiguration of the ground floor area consisting of a new ancillary storage area to the proposed building's eastern elevation measuring 75sq.m, at mezzanine level; change of use of 57sq.m of warehouse floor area to staff facilities due to the following, addition of single storey fire protected corridor from Office A to in the south-west corner of the warehouse, overall 45sq.m floor area addition; addition of stairs from warehouse to mezzanine level, overall 12sq.m floor area addition; elevation alterations, introduction of covered glazed structure at the main Office entrance to the front (southern) elevation, overall height 6.18m; introduction of Integrated Modular Louvre System to Charging Area to the front (southern) and side (eastern) elevation; change of colour of southern elevation warehouse canopy to Anthracite; introduction of fire escape doors to the side (eastern) elevation; site plan alterations, omission of an existing roundabout and provision of revised road junction with an access/egress to the proposed development and to the existing Business Park; provision of a new boundary fence Type A to the southern and eastern site boundary; introduction of additional 26 HGV parking spaces to the western concrete yard (overall area 1547sq.m) and the omission of car parking at the same location; introduction of 8 van parking spaces (overall area 240sq.m) and rearrangement of the car parking spaces due to introduction of the above changes, plus addition of gas tank and generator; associated drainage layout adjustments due to the inclusion of the above alterations; all other details such as landscaping, external surface finishes etc. will remain as per the aforementioned granted planning applications.

Location: Kingswood Business Park, Baldonnel, Dublin 22.
Report Date : 22nd Feb 2022

Surface Water Report:

No Objection Subject To:

Flood Risk

No Objection Subject To

1.1 Submit a report to outline what flood risk there is if any of proposed development. If there is a food risk submit a report and drawing to show what mitigation measures are proposed for the site.

Water Services Planning Report

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
 - All new precast surface water manholes shall have a minimum thickness surround of 150mm Concrete Class B.
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
-

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Padraig Slye GE.

Date: _____

Endorsed: _____
Brian Harkin SEE.

Date: _____