

Planning and Development Act 2000 (as Amended)

Notice of Direct Planning Application to An Bord Pleanála in Respect of a Strategic Infrastructure Development (A proposed Electricity Transmission Development)

County Dublin (South Dublin County Council)

In accordance with Section 182A of the Planning and Development Act 2000 (as amended) Vantage Data Centers DUB11 Ltd., gives notice of its intention to make an application for permission/approval to An Bord Pleanála in relation to the proposed development described below.

The proposed development primarily comprises the provision of two no. 110kV underground transmission lines and a 110kV Gas Insulated Switchgear (GIS) substation compound along with associated and ancillary works and is described as follows:

The proposed 110kV GIS Substation Compound is to be located on lands to the south of those that are subject of an application for 2 no. data centres under South Dublin County Council Reg. Ref. SD21A/0241 and to the south of Falcon Avenue within Profile Park, and within an overall landholding bound to the north by Falcon Avenue, Profile Park; to the west by Casement Road, Profile Park; and to the east and south by undeveloped lands; and partly by the Digital Reality complex to the south-east within Profile Park, Clondalkin, Dublin 22. The site of the proposed development has an area of c. 3.19 hectares.

The proposed 110kV Gas Insulated Switchgear (GIS) Substation Compound includes the provision of a two storey GIS Substation building (with a gross floor area of 1,477sqm) (known as the Kilcarbery Substation), three transformers with associated ancillary equipment and enclosures, a single storey Client Control Building (with a gross floor area of 51.5sqm), lightning masts, car parking, associated underground services and roads within a 2.6m high fenced compound and all associated construction and ancillary works.

One proposed underground single circuit 110kV transmission line will connect the proposed Kilcarbery 110kV GIS Substation to the existing 110kV Barnakyle Substation to the west. The proposed transmission line covers a distance of approximately 274m within the townlands of Aungierstown and Ballybane, and Kilbride and will pass under the internal road network within Profile Park to where it will connect into the Barnakyle substation.

One proposed underground single circuit 110kV transmission line will connect the proposed Kilcarbery 110kV GIS Substation to the existing 110kV underground Castlebaggot - Barnakyle circuit to the west within the Grange Castle South Business Park. The proposed transmission line covers a distance of approximately 492m within the townlands of Aungierstown and Ballybane, and Kilbride and will pass both under, and to the north of the internal road network within Profile Park and Grange Castle Business Park South where it will connect into the Castlebaggot - Barnakyle circuit at a proposed new joint bay.

The development includes the connections to the two substations (existing and proposed) as well as to the Castlebaggot - Barnakyle circuit, associated underground services, and all associated construction and ancillary works.

An Environmental Impact Assessment Report has been prepared in respect of this application.

The planning application and the Environmental Impact Assessment Report may be inspected free of charge or purchased on payment of a specified fee (which fee shall not exceed the reasonable cost of making such copy) during public opening hours **for a period of seven weeks commencing on the 25th February 2022** at the following locations:

- The Offices of An Bord Pleanála, 64 Marlborough Street, Dublin 1.
- South Dublin County Council, County Hall, Town Centre, Tallaght, Dublin 24.

The application may also be viewed/downloaded on the following website: www.KilcarberySID.ie

Submissions or observations may be made only to An Bord Pleanála ('the Board'), 64 Marlborough Street, Dublin 1 during the above-mentioned period of seven weeks relating to:

- (i) the implications of the proposed development for proper planning and sustainable development, and
- (ii) the likely effects on the environment of the proposed development, and
- (iii) the likely significant effects of the proposed development on a European site, if carried out.

Any submissions/observations must be accompanied by a fee of €50 (except for certain prescribed bodies) and must be received by the Board not later than 5.30 p.m. on the **14th April 2022**. Such submissions/observations must also include the following information:

- The name of the person making the submission or observation, the name of the person acting on his or her behalf, if any, and the address to which any correspondence relating to the application should be sent,
- The subject matter of the submission or observation, and
- The reasons, considerations and arguments on which the submission or observation is based in full. (Article 217 of the Planning & Development Regulations refers).

Any submissions or observations which do not comply with the above requirements cannot be considered by the Board.

The Board may at its absolute discretion hold an oral hearing on the application. (For further details see 'A Guide to Public Participation in Strategic Infrastructure Development' on the Board's website www.pleanala.ie).

The Board may in respect of an application for permission/ approval decide to-

- (a) (i) grant the permission/approval, or
- (ii) make such modifications to the proposed development as it specifies in its decision and grant permission/approval in respect of the proposed development as so modified, or
- (iii) grant permission/approval in respect of part of the proposed development (with or without specified modifications of it of the foregoing kind),

and any of the above decisions may be subject to or without conditions, or

- (b) refuse to grant the permission/approval.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Tel. 01- 8588100). A person may question the validity of any such decision by the Board by way of an application for judicial review, under Order 84 of the Rules of the Superior Courts (S. I. No.15 of 1986, as amended), in accordance with section 50 of the Planning and Development Act, 2000, as amended. Practical information on the review mechanism can be accessed under the heading Information on cases / Weekly lists - Judicial review of planning decisions on the Board's website www.pleanala.ie or on the Citizens Information Service website www.citizensinformation.ie.



Signed:
(Anthony Marston – Marston Planning Consultancy - Agent)

Date of Erection of Site Notice: **16th of February 2022**