

Water Services Planning Report

Register Reference: SDZ21A/0020 AI
Development: Minor amendments to the development permitted under Planning Permission Ref SDZ21A/0007 comprising the following: repositioning of landscaped communal courtyard of Block G from first floor podium level to ground floor level due to removal of podium parking at Level 0, and the consequential relocation of 83 car parking spaces within the Block F multi-storey car park (as permitted under Ref SDZ20A/0008, amended by SDZ20A/0018 and as further amended under a concurrent application under Ref SDZ21A/0017) and to on-street locations immediately adjacent to Block G, all including ancillary site development and landscape works; modification of 174 apartments (74 one-bedroom units, 98 two-bedroom units and 2 three-bedroom units) arising from adjustments to structural grids in Block G consequent to repositioning of the car parking and the landscaped courtyard; adjustments to Block G2 consisting of a minor reduction to the footprint of the Block by 0.6m and the removal of the setback floor on the northern half of the block (level 5), the reduction in height (1 floor) to the northern half of Block G2 (now 5 storey), a minor reduction to the overall provision of residential units from 185 to 184 apartment units, a minor reduction to the overall provision of car parking spaces from 93 to 92 spaces, a minor reduction to the overall provision of bicycle parking spaces from 225 to 224 spaces, the introduction of 9 ground floor units, facilitated by the removal of the podium from the core, the introduction of an additional apartment unit on Level 1, adjustments to the location of the bicycle, plant, and waste stores serving Block G, including the provision of bicycle storage structures in the courtyard; the development now proposed in Block G comprises of 184 apartments in a mix of 83 one-bedroom units, 99 two-bedroom units, 2 three-bedroom units, in two blocks (Block G1 ranges in height from 4 to 9 storeys and Block G2 ranges in height from 4 to 6 storeys; both including set back floors).

Location: Townlands of Gollierstown, Adamstown, Lucan, Co. Dublin
Applicant: Quintain Developments Ireland Limited
App. Type: Permission
Date Received: 8 -Feb-2022
Report Date: 17th Feb 2022

Water Services Planning Report

Surface Water Report:

No Objection Subject to:

1.1 Include SuDS (Sustainable Drainage Systems) features for the development including but not limited to:

- Permeable pavement
 - Tree pits
 - Swales
 - Rain Gardens
 - Green/Blue roofs
-
- All works shall comply with the Building Regulations -Technical guidance document- Part H Drainage and Wastewater disposal
 - The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.

Flood Risk Report:

No Objection

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Brian Harkin SEE

Date: _____

Endorsed: _____
Chris Galvin SE

Date: _____