

Water Services Planning Report

Register Reference No.: SD22A/0022

Development: The construction of a 2-storey extension and any associated site works to the south elevation of the existing engineering stores in the administration offices building which comprises of construction of circa 34sq.m area with a maximum height of 9.4m to accommodate two storey units at Grange Castle Business Park, Grange Castle, Dublin 22. The application relates to development which comprises of an activity, which requires an Industrial Emissions Licence in accordance with the First Schedule of the EPA Act 1922 as amended.

Location: Takeda Ireland Limited, Grange Castle Business Park, Clondalkin, Dublin 22

Report Date : 22nd Feb 2022

Surface Water Report:

No Objection:

Flood Risk

No Objection

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works
-

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Padraig Slye GE.

Date: _____

Endorsed: _____
Brian Harkin SEE.

Date: _____