

# Water Services Planning Report

**Register Reference:** SD22B/0007  
**Development:** (1) Conversion of attic space to non-habitable space with dormer window to rear and (2) single storey porch to front of existing dwelling and all associated site works.  
**Location:** 29, Rushbrook Grove, Dublin 6w  
**Applicant:** Alison and Andrew Cullen  
**App. Type:** Permission  
**Date Received:** 14-Jan-2022  
**Report Date:** 11<sup>th</sup> February 2022

## Surface Water Report:

**No Objection Subject to:**

- All works shall comply with the Building Regulations -Technical guidance document- Part H Drainage and Wastewater disposal
- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
- All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.

---

## Flood Risk Report:

**No Objection**

---

## Water Report:

**Referred to IW**

## Foul Drainage Report:

**Referred to IW**

Signed: \_\_\_\_\_  
Ronan Toft AE

Date: \_\_\_\_\_

Endorsed: \_\_\_\_\_  
Brian Harkin SEE

Date: \_\_\_\_\_