

Client:



HAZARD IDENTIFICATION LEGEND:

HAZARD IDENTIFICATION (if none state 'none relevant')	CONTROL AND MITIGATION MEASURES

NOTE: Hazards listed above are only those considered significant risks and:

- a) not likely to be obvious to a competent contractor or other designers;
- b) unusual; or
- c) likely to be difficult to manage effectively

KEY

- SITE ACCESS ROAD (A=2.165m² / c=0.8)
- GRAVEL (A=2.940m² / c=0.5)
- PERMEABLE ASPHALT TYPING (A=3.212m² / c=0.6)
- BUILDING FLOOR SLABS (A=2.207m² / c=1.0)
- LANDSCAPED AREAS (REF LANDSCAPE ARCHITECTS PLANS) (A=7.776m² / c=0.8)
- CONCRETE SERVICE YARD (A=2.033m² / c=0.8)
- CONCRETE FOOTPATH (A=1.876m² / c=0.8)
- STANDARD ROAD TARMAC (A=1.103m² / c=0.8)
- PLANTED MEADOW (POSSIBLE FUTURE DEVELOPMENT) (A=3.080m² / c=0.8)
- 150mm CONC UPSTAND (A=0.9F / c=0.8)

PLANNING REGISTRATION REFERENCE: SD21A/0186

DESIGN ISSUE
 THE DESIGN IS SUBJECT TO PLANNING APPROVAL AND DETAILED DESIGN.

REV	DATE	DESCRIPTION	DWN CHK APP
PRD	08.02.22	CF RESPONSE	FJR/UM
PR2	17.02.21	ISSUED FOR TENDER	FJR/UM
PR1	02.02.22	ISSUED FOR APPROVAL	FJR/UM

Key:

Project: EQUINIX DB081

Drawing Title: EXTERNAL WORKS LAYOUT

Drawing Number: DB080-PIN-00-ZZ-DR-C-PLAN-1211

Scale: 1:500 Paper Size: A1 Purpose: D2 Revision: P0

PINNACLE
CONSULTING ENGINEERS

SIXTH FLOOR PROSPECT HOUSE 100 NEW OXFORD STREET LONDON WC1A 1HB Tel: 0207 0433410

