

Register Ref: SD22A/0039

Development: (a) The demolition of two existing habitable structures on site including a bungalow (Silveracre), an existing cottage (No. 6 Whitechurch Road) and a row of 5 derelict structures/cottages located along the western boundary of the site (extent of proposed demolition is 433sq.m) (b) the construction of 22 4 bed, 3-4 storey units ranging in size from 197sq.m to 214sq.m, all with associated private balcony/terrace areas. Vehicular and pedestrian access is proposed via new entrance on Whitechurch Road. The proposed development shall provide for 44 car parking spaces, a new single storey bicycle storage shed (approx 34sq.m) and provision of bin storage to be provided at the front curtilage of the dwelling for all terraced units, all boundary treatment, all site services and all associated site works.

Location: Silveracre bungalow, Whitechurch Road, Rathfarnham, Dublin 14

Applicant: Dungrey Ltd

Application Type: Permission

Planning Officer:

Development Summary

This application is for the demolition of existing habitable structures and 5 derelict structures on the site and the construction of 22 4 bed units, car parking spaces, bicycle store and bin store.

Decision:

Noise pollution and air pollution restrictions will be necessary for the construction phase.

The above proposal **is acceptable** to the Environmental Health Department subject to the following conditions:

Noise Control

1. To control, limit and prevent the generation of Environmental Noise Pollution from occurring the Environmental Health Department of South Dublin County Council, hereby informs you that :

The use of machinery, plant, or equipment (which includes pneumatic drills, generators and the movement on and off the site of construction vehicles) is NOT PERMITTED outside the following hours

- Before 07.00 hours on weekdays, Monday to Friday
- Before 09.00 hours on Saturdays.
- After 19.00 hours on weekdays, Monday to Friday.
- After 13.00 hours on Saturdays.
- Not permitted at any time on Sundays, Bank Holidays or Public Holidays.

Reason: In the interest of public health by the prevention of unacceptable levels of noise pollution which could interfere with normal sleep and rest patterns and/or when people could reasonably expect a level of quietness, the proper planning and sustainable development of the area and to uphold the Council's amenity policies set out in the South Dublin County Council Development Plan.

Air Quality

2. During the construction / demolition phase of the development, Best Practicable Means shall be employed to minimise air blown dust being emitted from the site. This shall include covering skips and slack-heaps, netting of scaffolding, daily washing down of pavements or other public areas, and any other precautions necessary to prevent dust nuisances.

Reason: To contain dust arising from construction / demolition in the interests of public health and to prevent nuisance being caused to occupiers of buildings in the vicinity.

Gillian Wynne
Senior Environmental Health Officer
3rd March 2022

David O'Brien
Principal Environmental Health Officer
3rd March 2022