

Water Services Planning Report

Register Reference: SD22B/0024
Development: Attic conversion for storage with dormer window to rear;
four new roof windows to the front.
Location: 10, Knocklyon Drive, Ballyroan, Dublin 16.
Applicant: Kevin O'Brien & Marina Veillot
App. Type: Permission
Date Received: 24-Jan-2022
Report Date: 28th February 2022

Surface Water Report:

No Objection Subject to:

Flood Risk Report:

No objection subject to:

-
- All works shall comply with the Building Regulations -Technical guidance document- Part H Drainage and Wastewater disposal
 - The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
-

Water Report:

Not Applicable

Foul Drainage Report:

Not Applicable

Signed: _____
Ronan Toft AE

Date: _____

Endorsed: _____
Brian Harkin SEE

Date: _____