

**Irish Water's Statutory
Response to**

South Dublin

Planning Authority



Uisce Éireann
Bosca OP 6000
Baile Átha Cliath 1
Éire

Irish Water
PO Box 6000
Dublin 1
Ireland

T: +353 1 89 25000
F: +353 1 89 25001
www.water.ie

Planning Application No.

SD22A/0035

Date Lodged with Planning Authority:

07/02/2022

Development:

(a) Construction of a 4 storey nursing home building consisting of: (i) 106 bedrooms (with ensuite); (ii) associated residents welfare facilities; (iii) administration areas and staff facilities; (iv) multi-function space and pharmacy proposed at ground level; (b) construction of 60 one bed independent living units in 3 blocks as follows: (1) Block A, a 4 storey building comprising 11 one-bed units; (2) Block B, a part 4/part 5 storey building comprising 35 one-bed units; and (3) Block C, a 5 storey building comprising 14 one-bed unit. Each unit will be provided with a private open space in the form of a balcony terrace (6sq.m.) (c) The development will include communal open space and landscaping (including new tree planting and tree retention), 30 car park spaces (including 3 limited mobility parking spaces; 3 EV parking and 1 car sharing spaces); and 52 bicycle parking spaces (d) The development will be served by a new pedestrian and vehicular access from Old Greenhills Road through existing boundary wall. Material from the removed wall will be repurposed within the landscape areas; and (e) The development includes landscaping, boundary treatments (including wells and railings to southern and western boundaries), and ESB Substation SuDs drainage, road infrastructure and all ancillary site works necessary to facilitate the development.

Location :

Lands within St Marys Priory, Old Greenhills Road, Tallaght, Dublin 24

IW Recommendation:**Further Information Required****IW Observations:****1 Water**

1.1 Submit a pre connection enquiry with Irish Water for proposed development.

1.2 Obtain a letter of confirmation of feasibility of proposed development and submit same to Water Services South Dublin County Council Planning Authority.

1.3 Submit a drawing showing the watermain layout of proposed development. Maps of the public watermains networks may be obtained, if available, for required locations in by emailing: datarequests@water.ie.

- Where the applicant proposes to connect to a public water network operated by Irish Water, the applicant must sign a connection agreement with Irish Water prior to the commencement of the development and adhere to the standards and conditions set out in that agreement.

Reason: In the interest of public health and to ensure adequate water facilities.

2 Foul

1.1 Submit a pre connection enquiry with Irish Water for proposed development.

1.2 Obtain a letter of confirmation of feasibility of proposed development and submit same to Water Services South Dublin County Council Planning Authority.

1.3 Submit a drawing showing the waste water layout of proposed development. Maps of the public wastewater networks may be obtained, if available, for required locations in by emailing: datarequests@water.ie.

- Where the applicant proposes to connect to a public water network operated by Irish Water, the applicant must sign a connection agreement with Irish Water prior to the commencement of the development and adhere to the standards and conditions set out in that agreement.

Reason: In the interest of public health and to ensure adequate waste water facilities.

Signed on Behalf of Irish Water:

Yvonne Harris

Date:

13/03/2022

