

**Irish Water's Statutory
Response to**

South Dublin

Planning Authority



Uisce Éireann
Bosca OP 6000
Baile Átha Cliath 1
Éire

Irish Water
PO Box 6000
Dublin 1
Ireland

T: +353 1 89 25000
F: +353 1 89 25001
www.water.ie

Planning Application No.

SD22B/0061

Date Lodged with Planning Authority:

14/02/2022

Development:

Demolition of an existing shed (25sq.m) to the rear, and the construction of a new part single storey (43sq.m) and part two storey (17sq.m) pitched roof extension to the rear, the installation of roof lights to the existing roofs and all associated site works.

Location :

157, 'Cottages', Old Court Road, Tallaght, Dublin 24

IW Recommendation:**Further Information Required****IW Observations:****1 Water**

1.1 All development shall be carried out in compliance with Irish Water Standards codes and practices.

2 Foul

2.1 It is unclear where the foul water discharges from the proposed development. The applicant is required to submit a drawing showing existing and proposed foul water drainage layouts up to and including the point of connection to the public foul water sewer. The drawing shall include the location of all AJs, manholes, pipe size, material type and direction of flow. The drawing shall clearly show that the foul and surface water systems are discharging to separate pipe networks. Maps of the public watermains and Wastewater drainage networks may be obtained, if available, for required locations in by emailing: datarequests@water.ie.

2.2 All development shall be carried out in compliance with Irish Water Standards codes and practices.

Signed on Behalf of Irish Water:

Yvonne Harris

Date:

15/03/2022

