

**Irish Water's Statutory
Response to**

South Dublin

Planning Authority



Uisce Éireann
Bosca OP 6000
Baile Átha Cliath 1
Éire

Irish Water
PO Box 6000
Dublin 1
Ireland

T: +353 1 89 25000
F: +353 1 89 25001
www.water.ie

Planning Application No.

SD22A/0042

Date Lodged with Planning Authority:

10/02/2022

Development:

Construct a 25 metre high free standing monopole type structure carrying antenna and communication dishes within an existing 2.4m high palisade compound.

Location :

ESB Substation, Kennelsfort Road Upper, Palmerstown, Dublin 20

IW Recommendation:**Further Information Required****IW Observations:****1 Water (Further Information)**

1 There is no watermain drawing submitted. Submit a drawing showing existing surface water layout of proposed development.

Submit a drawing showing the distance between proposed development and existing 6" watermain south of same. There shall be a minimum setback distance of 3m from existing 6" watermain as per Irish Water Standards.

2 Alternatively obtain a confirmation of feasibility letter from Irish Water and submit same to Water Services Planning Authority
South Dublin County Council.

- All development shall be carried out in compliance with Irish Water Standards codes and practices.

Reason: In the interest of public health and to ensure adequate water facilities.

2 Foul (Not Applicable)

Signed on Behalf of Irish Water:

Yvonne Harris

Date:

15/03/2022

