

# Water Services Planning Report

**Register Reference No.:** *SD21A/0184 AI*

**Development:** Extension to the existing motor sales outlet with servicing area and associated development consisting of the construction of a single storey (double height) extension (c.568sq.m) to the existing motor sales outlet with servicing area which will comprise of a car body shop and valet area; single storey remote sales office (c.20sq.m); a covered bike shelter; ancillary petrol fill area; alterations to vehicle storage area; alterations and relocation of the exiting vehicle display provision (resulting in total of 79 defined display spaces (59 additional) together with indicative display areas with capacity for c.72 vehicles); a reduction in service spaces (resulting in total of 23 service spaces (3 less)) and relocation and additions to the existing staff car parking provision (resulting in total of 25 staff spaces (5 additional)); provision of a new pedestrian site entrance; signage (3 signs (4.45sq.m; 2.71sq.m; 0.58sq.m)); alterations and additions to the soft and hard landscaping, including the removal of existing fence; new boundary treatment and internal vehicle access gate; pedestrian paths and access; paving; tarmac and planting; relocation of vehicle sliding gate; an additional vehicle display podium; additional electric charging bays; new lighting; elevational changes to the existing building to facilitate the extension; an additional attenuation tank; all piped infrastructure and ducting; plant; all associated site development and excavation works above and below ground.

**Location:** Toyota Liffey Valley, Liffey Valley Motor Mall, Dublin 22

**Report Date :** 14<sup>th</sup> March 2022

---

## Surface Water Report:

**No objection:**

### **Flood Risk**

**No Objection:**

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
  - All new precast surface water manholes shall have a minimum thickness surround of 150mm Concrete Class B.
  - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
-

**Water Services Planning Report**

**Water Report:**

**Referred to IW**

**Foul Drainage Report:**

**Referred to IW**

Signed: \_\_\_\_\_  
Ronan Toft AE

Date: \_\_\_\_\_

Endorsed: \_\_\_\_\_  
Brian Harkin SE.

Date: \_\_\_\_\_