

Water Services Planning Report

43

Register Reference No.: SD22A/0034

Development: A 6.1sq.m single storey extension at the rear of the house linking the original kitchen to detached utility/playroom, conversion of playroom to kitchen and retention to increase in numbers of previously approved preschool sessional service on the ground floor from 10 to 16 children.

Location: 310 Glenview Park, Tallaght, Dublin 24

Report Date : 7th Mar 2022

Surface Water Report:

No Objection:

Flood Risk

No Objection

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works
-

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Padraig Slye GE

Date: _____

Endorsed: _____
Brian Harkin SEE.

Date: _____