

South Dublin County Council
An Rannóg Talamhúsáide, Pleanála agus Iompair
Land Use, Planning & Transportation Department
Telephone: 01 4149000 Fax: 01 4149104 Email: planning.dept@sdublincoco.ie

Jeremy Kelly
Unit 18, The Walk
Louisa Valley
Leixlip
Co. Kildare

PLANNING & DEVELOPMENT ACT, 2000 (as amended) AND PLANNING REGULATIONS THEREUNDER

Decision Order Number: 0350	Date of Decision: 22-Mar-2022
Register Reference: SD22B/0031	Registration Date: 27-Jan-2022

Applicant: Michael Melady
Development: Single storey side and rear extension.
Location: The Green, Main Street, Rathcoole, Co. Dublin.
Application Type: Permission

Dear Sir /Madam,

With reference to your planning application, received on 27-Jan-2022 in connection with the above, I wish to inform you that before the application can be considered under Section 33 of the Planning & Development Act 2000, six copies of the following **ADDITIONAL INFORMATION** must be submitted.

1. The applicant is requested to submit a landscaping plan for the site including, but not limited so, details on boundary treatments and the inclusion of Sustainable Urban Drainage Systems (SuDS). The existing front boundary walls, gate and defined boundary shall clearly be shown as retained and the side and rear boundary should complement these.
2. The applicant has not proposed any SuDS (Sustainable Drainage Systems) features for the proposed development. The applicant is requested to submit a drawing in plan and cross sectional views clearly showing proposed Sustainable Drainage Systems (SuDS) features for the development to manage excess surface water run off.

Note: Where a soakaway / infiltration system is proposed then the applicant is required to submit soil

percolation test results, design calculations and dimensions to the Planning Authority to demonstrate that the proposed soakaway is feasible in accordance with BRE Digest 365 – Soakaway Design. The applicant is also required to submit a drawing showing plan & cross-sectional views, dimensions, and location of proposed soakaway to the Planning Authority. Any proposed soakaway shall be located fully within the curtilage of the property and shall be:

- (i) At least 5m from any building, public sewer, road boundary or structure.
- (ii) Generally, not within 3m of the boundary of the adjoining property.
- (iii) Not in such a position that the ground below foundations is likely to be adversely affected.
- (iv) 10m from any sewage treatment percolation area and from any watercourse / floodplain.
- (v) Soakaways must include an overflow connection to the surface water drainage network.

NOTE: The applicant should note that any submission made in response to the above will be examined and MAY be deemed to be SIGNIFICANT ADDITIONAL INFORMATION by the Planning Authority. In this event the applicant(s) will be subsequently notified and requested to publish a notice in an approved newspaper and erect or fix a site notice on the land or structure to which the further information relates and to submit copies of the both the newspaper and site notices to the Planning Authority in accordance with Article 35 (1) (a) and (b) of the Planning and Development Regulations 2001 (as amended).

Note: The applicant must submit the Further Information within **6 months** of the **date of decision**. If the information is not received within this period the planning authority shall declare the application to be withdrawn.

Please ensure that your reply to this Request for Additional Information is accompanied by a covering letter marked “ADDITIONAL INFORMATION” and that the Planning Register Reference Number given above is quoted on the covering letter.

Signed on behalf of South Dublin County Council

Register Reference: SD22B/0031

Date: 23-Mar-2022

Yours faithfully,


for **Senior Planner**