

Water Services Planning Report

Register Reference: SD22B/0062
Development: New 2 storey extension to front, side and rear of family home, also single storey home office/storage to rear garden and all associated site works.
Location: 45, Homelawn Road, Dublin 24
Applicant: Darragh Satelle
App. Type: Permission
Date Received: 14-Feb-2022
Report Date: 15th March 2022

Surface Water Report:

Further Information Required:

- 1.1 There are no soil percolation test results, design calculations or dimensions submitted for the proposed soakaway. The applicant is required to submit a report showing site specific soil percolation test results and design calculations for the proposed soakaway in accordance with BRE Digest 365 – Soakaway Design.
- 1.2 The applicant is required to submit a revised drawing showing plan and cross-sectional views, dimensions, and location of proposed soakaway. Any proposed soakaway shall be located fully within the curtilage of the property and shall be:
 - i) At least 5m from any building, public sewer, road boundary or structure.
 - ii) Generally, not within 3m of the boundary of the adjoining property.
 - iii) Not in such a position that the ground below foundations is likely to be adversely affected.
 - iv) 10m from any sewage treatment percolation area and from any watercourse / floodplain.
 - v) Soakaways must have an overflow connection to the surface water network
- 1.3 The applicant shall include Water Butts and green roofs where feasible as part of additional Sustainable Drainage Systems (SuDS) measures for the proposed development.
- 1.4 Should a soakaway prove not to be feasible, then the applicant shall submit the following:
 - a) Soil percolation test results demonstrating a soakaway is not feasible
 - b) A revised surface water layout drainage drawing for the development showing the inclusion of alternative SuDS (Sustainable Drainage Systems) features.

Water Services Planning Report

Note: If the planning department decide to grant planning permission for this development, then the applicant shall submit the above information prior to commencement of development for written agreement from the Planning Authority.

- All works shall comply with the Building Regulations -Technical guidance document- Part H Drainage and Wastewater disposal

Flood Risk Report:

No objection subject to:

-
- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
-

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Ronan Toft AE

Date: _____

Endorsed: _____
Brian Harkin SEE

Date: _____