



LEGEND:

- WATER — PROPOSED 25mm PRIVATE WATERMAIN
- WATER — EXISTING WATERMAIN
- TALBOT BOUNDARY BOX (or similar approved) TO IRISH WATER REQUIREMENTS AS STATED IN IW-CIS-5020-03
- FIRE HYDRANT

NOTES:

1. ALL WATER MAINS TO BE INSTALLED IN ACCORDANCE WITH IRISH WATER SPECIFICATIONS AND TO IS EN 12201.
2. WATERMANS TO BE 25mm HDPE IN ACCORDANCE WITH IS EN 12201.

NOTES ON WATERMANS:

WATER MAINS SUITABLE FOR WORKS AND APPROVED BY IRISH WATER SHALL BE EITHER DUCTILE IRON (DI) OR POLYETHYLENE (PE), WITH PE80 OR PE100 RATING (HDPE, HDPE OR HPE). ALL PLASTIC WATER PIPES SHALL BE BLUE IN COLOUR. U-PVC PIPES SHALL NOT BE USED ON WATER SUPPLY NETWORKS. WATER MAIN MATERIALS ARE INDICATED BELOW.

PIPE SIZE (Ø) mm	PIPE MATERIAL
25 to 80	HDPE and MDPE
100 to 150	HDPE, MDPE and DI
200 to 300	HDPE, MDPE and DI
350 to 600	HDPE and DI
>600	DI

R 835

ISSUED FOR PLANNING

General Notes:-
 Contractors must verify all dimensions on the site before commencing work.
 Work only from figured dimensions.
 This drawing to be read in conjunction with all relevant Consultant's drawings.
 Reproduction of the whole or part of the information, ideas & concepts herein this drawing constitutes an infringement of copyright.

Revision Schedule	Initial	Rev	Date

Revision Schedule	Initial	Rev	Date

ISSUED FOR PLANNING	DF	1	21/02/2022
Revision Schedule	Initial	Rev	Date

PAMES DEVELOPMENTS LTD.
 First Floor, 60 Amiens Street, Dublin 1. Tel: 01 4950204, e-mail: info@pames.ie

Project: RESIDENTIAL DEVELOPMENT AT HILLVIEW, DISPENSARY LANE, LUCAN.
 Client: JOHN POPE
 Date: FEB 22
 Scale: 1:100
 Drawn: DF
 CAD Ref.
 Checked: TC
 Job No. 21010
 Drawing No. U-01