

Water Services Planning Report

Register Reference No.: SD22A/0058
Development: The installation of a 1.62m high, 0.87 m wide, 0.5m deep above ground natural gas pressure reduction cabinet and an accompanying 3.25m vent stack with all ancillary services and associated site works.
Location: Glenview Lawns, Tallaght, Dublin 24
Report Date : 21st Mar 2022

Surface Water Report:

No Objection:

Flood Risk

No Objection:

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
-

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Padraig Slye GE.

Date: _____

Endorsed: _____
Brian Harkin SEE.

Date: _____