

Water Services Planning Report

Register Reference No.: *SD21A/0249 AI*
Development: Construction of dormer bungalow and associated landscaping, services and parking resulting in no extra vehicular traffic to Killakee Green.
Location: 8, Firhouse Road, Tallaght, Dublin 24
Report Date : 25th Mar 2022

Surface Water Report:

No Objection Subject To:

Flood Risk

No Objection

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
 - All new precast surface water manholes shall have a minimum thickness surround of 150mm Concrete Class B.
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
-

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Ronan Toft AE.

Date: _____

Endorsed: _____
Brian Harkin SEE.

Date: _____